Fire Station Safety and Earthquake Early Warning Implementation Report 2025





Cal OES
GOVERNOR'S OFFICE
OF EMERGENCY SERVICES

Alfred E. Alquist Seismic Safety Commission

Improving the seismic safety and resiliency of California communities by providing resources and guidance, facilitating research, and fostering collaboration in earthquake preparedness, mitigation, and recovery.

---

(916) 263-5506 3650 Schriever Ave. https://ssc.ca.gov/

Table of Contents

Executive Summary **2**

---

1. Fire Station Data Collection Initiative **5**

Essential Services Buildings Seismic Safety Act (ESA) **5**

Practical Implications of Essential Services Act Compliance **6**

Building Code Improvements Since ESA **7**

Data Collected, Methods and Results **8**

2. Fire Station Seismic Risk Assessment **20**

3. Fire Station Design to Minimize Fire Hazard **22**

4. EEW Implementation Survey Results and Discussion **24**

5. Funding Opportunity Research **26**

6. Conclusion and 2026 – 2031 Work Plan **30**

Seismic Safety Commission
AB 1770 Report

Pursuant to Assembly Bill (AB 1770) — Fire Station Safety and Earthquake Early Warning Implementation
Submitted to:
Assembly Committee on Emergency Management
Senate Committee on Governmental Organization
Date: January 1, 2026

Executive Summary

Assembly Bill 1770 (Committee on Emergency Management, Chapter 212, Statutes of 2024 [1]) established new requirements for the Seismic Safety Commission (SSC or Commission) to coordinate with the Department of Forestry and Fire Protection (CAL FIRE) to take action relating to implementing and funding seismic mitigation activities and earthquake early warning (EEW) technology, including collecting related information on fire stations in California. Specifically, the Commission may coordinate with CAL FIRE and the Governor's Office of Emergency Services (Cal OES) to do any of the following:

> (A) Develop a list of all fire stations in California and each station's status in meeting the standards of the Essential Services Buildings Seismic Safety Act of 1986 (Health & Saf. Code, Section 16000 et seq.) to determine which stations are adequately designed and constructed to minimize fire hazards and to resist the forces generated by earthquakes, gravity, and winds.
>
> (B) Collect data on the implementation of earthquake early warning technology in all fire stations in California and their interest in implementing that technology.
>
> (C) Research other potential sources of funding for seismic mitigation activities.

1

The Commission has completed foundational work to collect information related to fire station vulnerabilities and readiness through a survey administered from December 2024 to April 2025. Out of the 3,500+ fire stations in California, the Commission received 1,037 responses, representing approximately one-third of all fire stations in the state. The survey methods and results are presented in Section 1 of this report. After further data cleaning, validation, and preprocessing, adjustments may be made in the next report.

To ensure the survey can collect the relevant information, meeting the requirements of the statute, the Commission used default building inventory data and other assumptions published in "The California Fire Station Seismic Risk Assessment and Retrofit Benefit Cost Study[2]". The high-level methodology, analysis, findings, and recommendations are included in Section 2, and the entire study can be accessed from the SSC website. The survey also included questions on the status of EEW adoption and interest. The findings are contained in Section 4. EEW pilot adoption and studies in fire stations are presented in coordination with the Cal OES EEW program.

CAL FIRE collaborated with SSC on the survey and presented information regarding the status of the fire stations related to fire hazards in Section 3. SSC researched and compiled potential sources of funding for seismic mitigation activities as of the date of this report. The funding sources are presented in Section 5.

Key Findings

1. **Many older fire stations are at risk** – Over 60% were built before the Essential Services Buildings Seismic Safety Act of 1986 took effect, and most have not been retrofitted.

2. **Backup power is limited** – One in four stations do not have generators, and, of those that do have generators, most have only three days of fuel on hand.

[2] California Seismic Safety Commission. *California Fire Station Seismic Risk Assessment and Retrofit Benefit Cost Study*. May 12, 2025. Available at: https://ssc.ca.gov/wp-content/uploads/sites/9/2025/06/Fire-Station-Risk-Assessment-Report_05122025_FINAL.pdf

3. **Adoption of earthquake early warning is minimal** – Fewer than 2% of stations have the system installed, but almost 40% want to learn more about it.

4. **Fire stations are critical to community safety** – More than 90% provide medical response, meaning vulnerabilities directly affect health and safety.

5. **Funding remains uncertain** – Changes to Federal Emergency Management Agency's (FEMA) Building Resilient Infrastructure and Communities (BRIC) program have left uncertainties and potential gaps, such that local agencies now rely heavily on alternative funding sources to pursue retrofits and safety upgrades.

This report outlines the SSC's actions, findings, and forward plans in coordination with CAL FIRE and Cal OES in compliance with AB 1770.

We report the compliance of Essential Services Buildings Seismic Safety Act (ESA) of 1986 per the statutory requirement. However, the building code has evolved significantly since 1986 and whenever new requirements are codified, they are not usually applied retroactively, unless a new addition or tenant improvement meets the threshold for evaluation and retrofit to bring the facility in line with newer building code sections. Therefore, one cannot assume the fire stations in compliance with the ESA are "adequately designed and constructed to minimize fire hazards and to resist the forces generated by earthquakes, gravity, and winds" per the current codes and standards. More discussions are in Section 1 and 3 of this report.

These findings are based on reported fire stations. The data collection efforts are ongoing.

1. Fire Station Data Collection Initiative

SSC developed a comprehensive survey instrument and collected responses from over 1,000 fire stations statewide between December 2024 and April 2025. Relevant data to the ESA are discussed below.

Essential Services Buildings Seismic Safety Act

This landmark legislation was enacted in 1986 with the following intent: "… essential services buildings, which shall be capable of providing essential services to the public after a disaster, shall be designed and constructed to minimize fire hazards and to resist, insofar as practical, the forces generated by earthquakes, gravity, and winds. It is also the intent of the Legislature that the structural systems and details outlined in working drawings and specifications be carefully reviewed by the responsible enforcement agencies using qualified personnel, and that the construction process be carefully and completely inspected. To accomplish these purposes, the Legislature intends to provide for the establishment of building standards for earthquake, gravity, fire, and wind resistance based upon current knowledge. It intends those procedures for the design and construction of essential services buildings be subjected to qualified design review and construction inspection."

Regarding the benchmark date for compliance, the Act stated: "Except as provided in Section 16011, on and after July 1, 1986, construction of an essential services building shall not begin unless the drawings and specifications comply with this chapter and the requirements prescribed by the enforcement agency and approval of those drawings and specifications has been obtained from the enforcement agency." Building departments usually use the construction plan and specification submission date to determine which code cycle applies, meaning that if plans were submitted after July 1, 1986, the plans would likely be subject to the requirements in effect in the ESA. In the survey instruction, SSC specially suggested, "please be sure to contact your local building official, public works department, or engineer of record to confirm…the date of construction." The building department or public works department would then reference the construction documents, which usually show the dates of plan approval, and report the date of construction. Assuming it takes one or two years from initial submission to obtaining plan approval, SSC can use July 1, 1988,

as the benchmark year for compliance. This means any fire station constructed after July 1, 1988, is deemed to comply with the ESA. Appendix A includes the list of fire stations constructed before July 1, 1986, those constructed between July 1, 1986, and July 1, 1988, as well as those constructed after July 1, 1988.

Practical Implications of ESA Compliance

Under the ESA, essential service buildings, such as fire stations, must be designed and constructed to withstand forces from earthquakes, fires, wind, and gravity. The following requirements accomplish this:

- *Engage Licensed Design Professionals:* Hire the appropriate licensed professionals for design and oversight. The law requires that the building's plans and specifications be prepared under the responsible charge of a California-licensed architect, civil engineer, or structural engineer.

- *Plan Review & Approval:* Review and approve building plans for essential services facilities to ensure they meet the State Building Standards Code or local model codes (as applicable). Staff the plan review with qualified professionals. The law requires that plan checking for essential services buildings be done under the responsible charge of a California-licensed architect, civil engineer, or structural engineer.

- *Construction Inspection:* Inspect the construction work as it progresses to verify that the building is being constructed according to the approved plans and specifications. The building owner is obligated to hire a qualified construction inspector, and the enforcement agency must require this as a condition of the permit. The inspector must have appropriate experience or certification (such as International Conference of Building Codes/International Code Council (ICBO/ICC) certification or equivalent Uniform Building Code (UBC) qualifications) in the type of construction being performed.

- *Site-Specific Geotechnical Study:* Required for any modification to structural elements of existing stations (unless exempted), ensuring site conditions (e.g., near-fault zones) are factored into seismic safety.

Building Code Improvements Since ESA Enactment

Since the 1986 enactment of the ESA, significant updates to California's building codes have improved seismic safety for essential service buildings. Notable updates include:

- **Seismic irregularity criteria:** Identifying problematic designs (like soft-story or torsional layouts) and restricting them first appeared in the 1988 Uniform Building Code (UBC). Essential facilities like fire stations, which often have large apparatus bay doors (open fronts can create irregularities), had to be carefully evaluated under these rules. This period also saw emphasis on redundancy – ensuring structures have multiple lines of seismic resistance – which was especially encouraged for important buildings to avoid single-point failures.

- **Detailing and Ductility Upgrades:** Lessons from the 1994 Northridge earthquake prompted urgent code changes in the 1994 and 1997 UBC (which California adopted with modifications). Northridge famously revealed brittle welded-steel moment-frame connections failing at beam-column joints. In response, interim code changes and bulletins (adopted into California's Building Code (CBC) in part in 1995, and entirely in 1998) moved away from pre-approved but inadequate connection details. For essential facilities, this had a significant impact: any new steel-frame fire station after 1994 had to use improved connection designs (with notch-tough weld metal, removed backing bars, and inspection regimes) or alternative lateral systems. Similarly, detailing requirements for concrete have become stricter over the years – e.g., increased confinement steel in beam-column joints – to ensure ductile energy dissipation. These changes meant that a fire station's structural frame would not only be stronger by design but also more robust in its joints and connections, able to deform without losing gravity support.

- **Performance Objective – Toward Immediate Occupancy:** While the building code's life-safety goal (to prevent collapse) remained the minimum requirement a building needed to satisfy, recognition of higher performance for essential facilities grew. FEMA's National Earthquake Hazards Reduction Program (NEHRP) guidelines published in 1994 introduced Seismic Performance Categories, tying occupancy to expected performance, which was later replaced by Seismic Design

Category in the provisions and the codes section of the 1997 NEHRP. For example, they envisioned that "essential facilities will remain operational during and following earthquakes," as distinct from non-essential service buildings, which only need to ensure life safety. California's practice mirrored this philosophy. In practical code terms, California implemented stricter drift limits and higher seismic design forces for essential facilities[3].

- **Emerging "Functional Recovery" Goals:** In the late 2010s, there has been a national push (including in California) toward formalizing functional recovery objectives for some buildings. While not yet fully realized in the code, California is laying the groundwork. This recovery philosophy for some buildings is consistent with the trajectory of improvement from 1986 to the present, with increasingly stringent expectations for performance. Some new emergency operations centers and fire stations are being designed with performance-based evaluations to ensure they meet Immediate occupancy requirements. Techniques such as base isolation and energy dissipation are also more frequently employed in essential facilities to eliminate downtime.

Whenever new requirements are codified, they are not usually applied retroactively, unless a new addition or tenant improvement meets the threshold for seismic evaluation and retrofit to bring the facility in line with newer building code sections. Therefore, one cannot assume the fire stations in compliance with the ESA are "adequately designed and constructed to minimize fire hazards and to resist the forces generated by earthquakes, gravity, and winds" per the current codes and standards. To determine their compliance with current seismic codes and standards, licensed professional engineers need to perform project-specific evaluation per the American Society of Civil Engineers (ASCE) 41 standard. However, since such evaluation is a resource-intensive activity, the data collected through this survey effort, as well as consequential risk assessment, will help the fire districts to plan and prioritize. See Section 2 for more detailed discussions.

Data Collected, Methods and Results

[3] S.K. Ghosh, "Trends in the Seismic Design Provisions of U.S. Building Codes," *PCI Journal*, Vol. 46, No. 5, September–October 2001, pp. 98–122. Available at: https://www.pci.org/PCI_Docs/Publications/PCI%20Journal/2001/Sept-Oct/Trends%20in%20the%20Seismic%20Design%20Provisions%20of%20US%20Building%20Codes.pdf

Recruitment and Survey Process

The SSC, in collaboration with the Cal OES Fire and Rescue Division, initiated a voluntary statewide survey of all fire stations in California to document building structures, preparedness levels, and critical services provided. Fire station personnel completed the survey electronically using the ArcGIS Survey123 tool. Guidance was provided for answering technical questions, and personnel were encouraged to consult licensed engineers or local building officials if needed.

Survey Development

Survey questions were informed by prior studies, including the *Seismic Risk Assessment for Fire Stations in the San Francisco Bay Area* (Earthquake Engineering Research Institute – Northern California Chapter (EERI-NC), 2006), and adapted to capture structural, non-structural, and service-related vulnerabilities. The survey questions are designed to balance the need to collect valuable information for high-level risk assessment while relying on fire station personnel, instead of trained engineers, as was enacted in the prior studies.

The statewide survey collected detailed information in six main categories:

1) Construction Characteristics: Year built, retrofit history, structural system (FEMA building type), number of stories, roof height, floor area, and foundation type.
2) Facility Use & Emergency Services: number of occupants, Emergency Medical Services (EMS) capability, distance to backup station, population served.
3) Backup Power: Fuel type, fuel duration in days, and power redundancy.
4) Apparatus Doors: Age, material, type, and whether they are connected to emergency power.
5) Disaster Preparedness: Status of local Emergency Operations Center (EOC) designation, seasonal operation schedule.
6) EEW System Readiness: Presence of earthquake early warning system, and level of interest if not currently installed.

The survey instrumentation is attached in Appendix C.

Software and Tools

Responses were analyzed using ArcGIS Pro to validate geolocation information, assess features such as population served and distance to adjacent EMS facilities, and visualize spatial relationships with seismicity and fire severity. Analytical modeling was employed using FEMA's Hazard U.S. (HAZUS) Advanced Engineering Building Module (AEBM), and data preprocessing and visualization were conducted using Python (version 3. x) within the Google Colab environment.

Survey Period

The fire station survey was distributed statewide between late 2024 and early 2025, with support from Cal OES. Before complete distribution, the instrument was pilot tested with selected fire stations to ensure clarity and validity of the questions. This approach enhanced the appropriateness of the measurement for the study design and strengthened content validity.

Results

The list of all the fire stations in California is based on HAZUS building inventory, which is open source maintained by FEMA. Some fire stations are included in the survey result but not in HAZUS inventory list; one of the reasons might be that they were built after the HAZUS data collection date. The auxiliary buildings to support the fire stations are not included.

Analysis of 1,037 California fire station survey entries reveals critical insights. Key findings include:

- 92.3% of stations provide EMS
- 6.7% serve as an EOC
- 60.9% of stations were constructed before July 1, 1986
- 96.7% of pre-1988 fire stations lack seismic retrofit
- 25.5% of stations have no backup power generator on site
- Emergency fuel reserves 3 days (median)

Detailed findings are below.

1. Fire Station Construction Period Analysis

The survey captured construction year data for 1,036 stations. The fire stations constructed before July 1, 1986, are non-ESA-compliant; the fire stations built between July 1, 1986, and July 1, 1988, may be ESA-compliant, but not with certainty. The fire stations constructed after July 1, 1988, are deemed ESA-compliant. The fire stations built between July 1, 1986, and July 1, 1988, as well as those built after July 1, 1988, are listed in Appendix A. The counts are below:

- **Before 7/1/1986**: 631 stations (60.9%)
- **7/1/1986 - 7/1/1988**: 24 stations (2.3%)
- **After 7/1/1988**: 381 stations (36.8%)

The histogram of construction years in Figure 1b shows peaks in the 1950s-1960s and 2000s-2010s, indicating two significant periods of fire station construction in California. Critically, 60.9% of surveyed California's fire stations were built before July 1, 1986, making them potentially vulnerable to seismic events without ESA compliance.




Figure 1a and b. Fire Station Construction Periods. Figure 1a illustrates the number of buildings pre- and post-1986 ESA.

2. Seismic Retrofit Status

Among the 655 fire stations constructed before 1988:

- **No Retrofit Performed**: 633 stations (96.6%)
- **Retrofit Completed**: 22 stations (3.4%)

The Commission's research suggests that this represents critical infrastructure vulnerability, as these older stations were built before modern seismic building codes were implemented. The lack of retrofitting can pose significant risks to emergency response capabilities during earthquakes.




Figure 2. Seismic Retrofit Status of Pre-1988 Fire Stations

3. Building Construction Types (FEMA Building Type Classification)

The distribution of surveyed building types reveals that over half of fire stations are constructed of wood frame. See Figure 3 below.




Figure 3. Distribution of Fire Station Building Types (FEMA Classification)

See Appendix C for more information on FEMA building type classification.

4. Station Setting Classification

After data cleaning to remove erroneous entries on the station setting classification, the distribution in Figure 4 shows:

- **Rural/Non-Urban - Paid Fire Departments**: 492 stations (47.6%)
- **Urban - Paid Fire Departments**: 484 stations (46.9%)
- **Rural/Non-Urban - Volunteer Fire Departments**: 57 stations (5.5%)

The near-equal split between urban and rural settings highlights the diverse operational environments of California's fire stations.




Figure 4. Fire Station Setting Classification (Urban vs. Rural)

5. Emergency Medical Services Provision

- **Provide EMS**: 957 stations (92.3%)
- **Do Not Provide EMS**: 80 stations (7.7%)

The high percentage of fire stations in Figure 5 providing EMS demonstrates the integrated nature of emergency services in California, with fire departments serving as critical components of the medical emergency response system.




Figure 5. Emergency Medical Services Provision Among Fire Stations

6. Emergency Operations Center (EOC) Designation

- **Designated as EOC**: 69 stations (6.7%)
- **Not Designated as EOC**: 968 stations (93.3%)

Only a small fraction of fire stations serve as EOCs, as shown in Figure 6.




Figure 6. Emergency Operations Center Designation


7. Backup Power Generator Fuel Source

One in four fire stations lacks a backup power generator on site, as shown in Table 1, representing a significant vulnerability during power outages that often accompany natural disasters.

Table 1 Primary backup power fuel sources.

Fuel Source	Count	Percentage
Diesel	529	51.0%
No Generator	264	25.5%
Propane	163	15.7%
Natural Gas	38	3.7%
Regular Gasoline	38	3.7%
Other	5	0.5%

Figure 7. Backup Power Generator Fuel Sources



8. Emergency Fuel Reserves

For stations with backup power[4] (726 valid responses):

- **Median**: 3 days
- **Mean**: 16.8 days
- **Mode**: 3 days (most common)
- **Range**: 0 to 1000 days (there might be a data quality issue for the maximum value)

9. Apparatus Door Age

Analysis of 990 stations with door installation year data in Figure 8 shows:

- **Median Installation Year**: 1999
- **Stations with doors over 20 years old**: 676 (68%)
- **Stations with doors over 30 years old**: 450 (45%)

Many stations operate with aging apparatus doors that may not meet current safety standards or operational requirements.

[4] *"Per California Electrical Code/National Electrical Code Articles 700–702, most fire station generators are classified as Article 702 Optional Standby Power, unless specifically required for emergency or legally required standby loads."*




Figure 8. Apparatus Door Age Distribution

2. Fire Station Seismic Risk Assessment

The California Fire Station Seismic Risk Assessment and Retrofit Benefit Cost Study, initiated by the SSC as Phase I of AB 1770 compliance effort explores seismic risks associated with fire stations and evaluates the benefits of potential retrofit solutions. This assessment employs FEMA's HAZUS AEBM and the Benefit-Cost Analysis (BCA) Toolkit Earthquake Structural Model. The study uses default building data to evaluate seismic vulnerabilities and retrofit benefits, quantifying costs and benefit-to-cost ratios associated with upgrading fire stations from Moderate Code (MC) to High Code (HC) or Special High Code (HS). Hazard calculations were based on the 2018 United States Geological Survey (USGS) national seismic hazard model, which includes adjustments for local site-soil conditions.

Retrofit costs were estimated using FEMA-156 "Typical Costs for Seismic Rehabilitation of Existing Buildings," considering factors such as building type,

area size, seismicity/performance objectives, location adjustments, and construction cost indices. Assumptions include building occupancy, distance to the nearest alternative EMS providers, and the size of the population served by each station. Loss calculations included structural damage, non-structural damage sensitive to drift (such as interior and exterior wall elements), acceleration (such as mechanical, electrical, plumbing systems), contents damage, casualty estimates, and loss-of-function impacts, particularly highlighting disruptions to EMS services. This study provided insights that guided the development of targeted survey questions, to collect detailed, station-specific data to enhance risk assessment accuracy and reduce uncertainties.

Findings

Incorporating loss-of-function into benefit calculations significantly improved benefit-cost ratios, particularly for fire stations providing EMS, which constitute approximately 67.6% of calls statewide.

Current methodologies, as applied to this case study, support retrofit to HC. Retrofit to HS likely requires more detailed project-specific calculations of the benefits to justify the higher upfront costs.

Operational vulnerabilities, notably seismic impacts on fire station garage doors, were highlighted by events such as the 2022-23 Ferndale earthquake sequence. A follow-up conversation exposed critical gaps in current building code standards and industry specifications for roll-up door functionality after seismic events.

Recommendations

Based on findings, the study recommends an integrated seismic risk management approach, prioritizing seismic retrofit based on service criticality, particularly for fire stations serving large populations or those remote from alternative EMS. It advocates continued refinement and adoption of improved risk assessment tools such as HAZUS and the BCA Toolkit, emphasizing detailed, up-to-date seismic hazard integration and the quantification of broader community benefits related to service continuity.

Additionally, the report emphasizes the importance of addressing operational vulnerabilities, such as garage door functionality, and urges the development and enforcement of industry performance standards aligned with essential facility continuous operationality requirements. Exploring EEW-activated systems for garage door openers in existing fire stations is also recommended.

Next Steps

Moving forward, the SSC will refine seismic risk assessments utilizing the detailed, site-specific data collected from the surveys. This phase aims to enhance assessment accuracy and inform strategic prioritization and funding decisions for seismic retrofits more effectively. The deliverables will include average annualized loss (AAL), which will consider age, building type, size, seismicity, occupancy, the benefit of seismic retrofit, including loss avoidance due to structural, non-structural components, content, casualty, and community benefit of an operational fire station. The Commission plans to present the information in a report and a GIS dashboard.

3. Fire Station Design to Minimize Fire Hazard

The SSC coordinated with CAL FIRE to determine which fire stations are adequately designed and constructed to minimize fire hazards.

California has made significant changes to its building codes to improve fire and life safety since the ESA era. For example, in 2007, California adopted the International Building Code (IBC 2006). The IBC classifies fire stations as mixed occupancies (B/R/S) and encourages the use of sprinkler systems under the National Fire Protection Association (NFPA) Standard for the Installation of Sprinkler Systems (NFPA 13).

For stations located in wildland-urban interface areas, CBC Chapter 7A mandates that buildings permitted after July 1, 2008, utilize construction methods that resist wildfire flames and ember intrusion utilizing exterior materials. Many older stations built with combustible roofs or vents are vulnerable to embers and may need retrofits.

The 2010/2011 version of the CBC updated egress, occupancy, and structural provisions. A significant statewide change required automatic fire sprinklers in all new one- and two-family dwellings. Although it was primarily directed at

housing, this requirement reinforced the trend toward universal sprinklers. The code also introduced stricter criteria for smoke detection and carbon-monoxide alarms in all occupancies.

The 2013–2016 CBC updates (IBC 2012/2015) refined mixed-occupancy provisions, clarified occupant-load factors, and introduced new requirements for apparatus-bay ventilation and carbon-monoxide detection.

The 2022 version of the CBC (effective January 1, 2023) adds clarifications for smoke-detection spacing, carbon-monoxide detection, and energy storage systems. It also carries forward prior Wildland-Urban Interfaces (WUI) and accessibility provisions.

Therefore, common issues for older fire stations that impact their fire and life safety protection include:

- Lack of sprinklers and hazard detection – Many pre-2000 stations were not sprinklered and may have had limited smoke or carbon monoxide detection capabilities. The U.S. Fire Administration (USFA) recommends retrofitting sprinklers, at a minimum, in the apparatus bay, because most station fires originate in apparatus, according to the USFA's Report on Safety and Health Considerations for the Design of Fire and Emergency Medical Services Stations.[5] Older electrical systems may lack sufficient capacity or be ungrounded, thereby increasing the fire risk. Absence of supervised alarms delays detection and evacuation.
- Combustible construction & inadequate fire separation – Older one-story volunteer stations often used Type V (combustible) construction and lacked fire-resistance-rated separations. Without sprinklers, fires in the apparatus bay can rapidly spread to living areas. WUI-designated stations built before 2008 may have combustible roofs, siding, and vents that permit ember intrusion.

Appendix B shows the locations of fire stations in various fire severity zones.

[5]U.S. Fire Administration. *Safety and Health Considerations for the Design of Fire and Emergency Medical Services Stations*. U.S. Department of Homeland Security, Federal Emergency Management Agency. Available at: https://www.usfa.fema.gov/downloads/pdf/publications/design_of_fire_ems_stations.pdf
Let me know if you'd like a shortened citation for inline use or a bibliography-style reference list.

4. EEW Implementation Survey Results and Discussion

In partnership with Cal OES, the SSC collected data from fire departments on the implementation and interest in the California Earthquake Early Warning System (CEEWS), powered by ShakeAlert.

Survey Findings

Among 1,037 surveyed fire stations:

- **EEW System Installed**: 11 stations (1.1%)
- **No EEW System**: 1,026 stations (98.9%)




Figure 9. EEW System Implementation Status

When asked, "Would you be interested in learning more about the earthquake early warning (EEW) technology and funding opportunities?":

- **Yes**: 398 stations (38.4%)
- **No**: 599 stations (57.8%)
- **No Response**: 40 stations (3.9%)




Figure 10. Fire Station Interest in EEW Technology

This extremely low adoption rate, combined with high interest in learning more, indicates opportunities to help California's first responders leverage advanced warning of incoming shaking, to take protective actions such as Drop, Cover, and Hold, open apparatus bay doors, and initiate other emergency protocols.

As part of Cal OES's goal to expand EEW implementation throughout California, a feasibility study for airports was commissioned to assess the challenges and cost-benefit ratio of adopting EEW at airports. In this study, two case studies were used to illustrate the real-world challenges, benefits, and costs associated with the implementation of EEW at fire stations located within airports. For example, Los Angeles International Airport (LAX) has three fire stations on-site. One focus of the study estimated that automating the opening of fire station bay doors, in response to EEW notifications at LAX, could yield a total benefit of over $1.05 million over 50 years. Given the significant quantified benefits and the low risk of false positives, this type of implementation has been identified as a high priority for the airport.

Another approach Cal OES is taking to make EEW more widespread across California and benefit its residents is focusing on emergency response. A one-time pilot was established to support fire stations in seismically active, socially vulnerable areas. The Los Angeles County Fire District and the Morongo Band of Mission Indians are participants in the pilot, which provides funding to implement EEW technology at their fire stations. The EEW automated actions they plan to integrate include opening fire station bay doors, shutting off gas and water valves, and issuing audio and visual alerts both inside and outside the station. Additionally, staff will receive direct text messages. The pilot project is expected to be completed by the end of 2025.

5. Funding Opportunity Research

To assess federal and state programs relevant to EEW systems, regional seismic mitigation strategies, and structural upgrades to fire stations, the Seismic Safety Commission (SSC) conducted a targeted funding review. This analysis draws in part from the 2023 Earthquake Warning California Legislative Report, which documents recent EEW implementation efforts and associated funding mechanisms. Because funding for seismic mitigation remains dynamic, this report reflects current conditions and will be supplemented as additional guidance becomes available. While several programs offer meaningful support, few directly fund the buildout of EEW systems or last-mile alert delivery. Care has been taken to avoid overstating the potential for funding or implying that any single or combined sources could support operational needs.

Funding Source Viability Summary

- The table below summarizes the applicability of each funding source to EEW systems, seismic mitigation, and fire station retrofitting. Because grant programs often distinguish between EEW system build-out (sensor networks, backbone infrastructure) and last-mile alert delivery (station-level devices, signage, protocols), the table reflects general eligibility. Specific scopes are clarified in program descriptions and Appendix D.

Program	EEW System (Build-Out vs. Last Mile)	Seismic Mitigation	Fire Station Eligibility	Key Limitations
FEMA HMGP	Limited (when integrated into mitigation plans)	Yes	Yes	Post-disaster only; no maintenance funding
NEHRP ISEA/MSNEA	Planning only	Limited	Yes (pilot scale)	Small awards, competitive, no construction funding

Cal OES Fire Station EEW Pilot Grant	Yes	No	Yes	One-time only; no future rounds guaranteed
FEMA PDM	Yes (when aligned with mitigation plans)	Yes	Yes	Competitive; cost-share required; subject to appropriations ; subject to approval by Congress via Congressionally-Directed Spending (CDS) requests
HUD CDBG	Planning and education only	Limited	Conditional	Must meet low-income or urgent need criteria; no EEW infrastructure funding.
USDA CF Program	No (direct)	Yes	Yes	Rural only; EEW is incidental to broader upgrades

Note: EEW eligibility varies by program. Some grants support last-mile alert delivery only, while others may fund limited system build-out when integrated into mitigation plans.

Program Descriptions and Recommendations
FEMA Hazard Mitigation Grant Program (HMGP)

The Hazard Mitigation Grant Program (HMGP) provides post-disaster funding to reduce future risks and strengthen community resilience. In California, the program is administered by Cal OES. Fire stations may be eligible applicants when proposed projects are included in FEMA-approved Hazard Mitigation Plans. Supported activities include seismic retrofitting, equipment anchoring, and installation of seismic isolation systems. Earthquake early warning (EEW) infrastructure—such as sensors and automated alert protocols—may also be eligible when integrated into broader mitigation strategies.
HMGP eligibility criteria and supported activities vary based on the nature and geographic impact of the declared disaster. Funding is only available following a Presidential Disaster Declaration, and annual allocations fluctuate with the severity of the disaster. FEMA's requirements for approved projects include cost-effectiveness, technical feasibility, and environmental compliance. EEW-related activities are exempt from cost-effectiveness thresholds only when they involve

seismic networks, geodetic networks, or sensor infrastructure. The program does not cover ongoing maintenance or operational costs.

Given its post-disaster nature and conditional scope, HMGP can be a viable but limited funding source. Clear communication is essential to avoid unrealistic expectations regarding availability and coverage.

NEHRP State Assistance Program (ISEA and MSNEA)

Administered by FEMA, the NEHRP State Assistance Program supports seismic risk reduction through planning, code updates, vulnerability assessments, and public education. Recent guidance confirms that fire station retrofitting is now an eligible activity under the ISEA program, provided projects align with hazard mitigation plans and demonstrate long-term risk reduction.
While NEHRP supports foundational assessments and coordination efforts, it does not typically fund full-scale construction or EEW infrastructure. EEW-related activities—such as sensor deployment and automated alert protocols—may be eligible when tied to planning and preparedness initiatives. Additionally, the limited funding available to California is not conducive to most EEW projects. However, the program is already being leveraged, when possible, for EEW education and outreach.

Recommendation: NEHRP could be considered a supplemental resource for planning and capacity-building rather than a primary funding source for EEW or major retrofits.

Cal OES EEW Implementation Pilot Grant for Fire Stations

In April 2024, Cal OES launched a one-time grant program to support EEW integration in fire stations, funding alerting infrastructure, with a performance period extending through December 2025. While impactful, the grant was not designed for seismic retrofitting or long-term EEW operations.
Future funding availability is contingent on additional appropriations, and no recurring rounds are guaranteed.

Recommendation: This grant serves as a precedent for targeted EEW funding, but is not a sustainable or repeatable source.

FEMA Pre-Disaster Mitigation (PDM) Grant Program

The PDM program, appropriated through Congressionally-Directed Spending (CDS) requests, funds proactive hazard mitigation projects that reduce risks to life and property. Eligible activities include seismic retrofitting, equipment anchoring, and EEW system integration, provided they are aligned with FEMA-approved hazard mitigation plans. EEW infrastructure is considered cost-effective when used to enhance regional seismic networks and emergency response capabilities.
Funding is competitive and subject to Congressional appropriations via CDS requests, also known as "earmarks." Applicants are required to meet cost-effectiveness and feasibility criteria, and most projects require a 75% federal / 25% non-federal cost share. Small, impoverished communities and Tribal Nations may qualify for up to 90% federal support.

Recommendation: The Pre-Disaster Mitigation (PDM) program remains a viable, though highly competitive, funding source. EEW eligibility is best viewed as conditional, subject to factors such as project design, alignment with FEMA priorities, as well as broader annual Congressional appropriations. This approach ensures flexibility while aiming for successful implementation.

HUD Community Development Block Grant (CDBG)

The CDBG provides funding for public facility improvements in low- and moderate-income communities. Fire station retrofits may qualify if they meet HUD's public benefit criteria. EEW-related planning and education efforts may also be eligible under the Planning and Technical Assistance (PTA) category. However, physical EEW infrastructure—such as seismic sensor networks—is not an eligible use of funds. Eligibility is highly dependent on local demographics, and seismic projects may be less competitive than housing or economic development priorities.

Recommendation: The CDBG should be presented as a potential supplemental source for planning or minor upgrades—not for core EEW infrastructure or major retrofits.

USDA Community Facilities (CF) Direct Loan and Grant Program

The USDA CF Program supports essential infrastructure in rural communities, including the construction, renovation, and retrofitting of fire stations. Eligible improvements include seismic reinforcement and hazard-resistant design. While the program does not directly fund EEW hardware, it may support related planning, coordination, and emergency preparedness efforts.
Eligibility is restricted to rural communities with populations under 20,000.

Recommendation: CF is a viable option for rural jurisdictions pursuing seismic retrofits. EEW references only pertain to planning and coordination activities.

Closing Summary

Taken together, these funding sources represent a diverse but fragmented landscape of support for seismic safety initiatives. While opportunities exist, they are often limited by eligibility constraints, competitive selection processes, or narrow scopes of allowable activities. Continued coordination across agencies and alignment with existing mitigation strategies will be essential to maximize available resources and advance California's seismic resilience goals. To support technical review and future updates, Appendix D provides expanded program notes and source citations.

6. Conclusion and 2026 – 2031 Work Plan

The SSC has met AB 1770's initial objectives by collecting relevant data to assess fire station risk, coordinating with CAL FIRE and Cal OES, and initiating the design of a reporting system and dashboard to disseminate information. Future work will focus on expanding data collection to the remaining fire stations and efforts to close seismic safety gaps, thereby improving community resilience.

2026 Priorities:

- Continue processing and analysis of the data collected through the survey
- Expand data collection to the remaining fire stations
- Launch technical assistance initiative for fire stations pursuing retrofits
- Release a GIS-based tool to visualize statewide fire station seismic readiness

Appendix A

List of all the fire stations in California that responded to SSC's survey and their status with ESA

Appendix B

Fire Stations Within Fire Hazard Severity Zones

Appendix C

Survey Instrument

Appendix D

Funding Source Details and Supplemental Notes

Disclaimer

This report is based on the SSC's best knowledge and good-faith effort to collect and analyze information through a statewide survey of fire stations. The SSC relied on self-reported data provided by fire station personnel. While every reasonable step was taken to ensure clarity in questions, validate responses, and perform due diligence in data cleaning and cross-checking, the SSC cannot guarantee the accuracy, completeness, or timeliness of the collected data.

Funding information presented in this report reflects research conducted as of the date of publication. Funding programs, eligibility criteria, and availability are subject to change and should not be construed as exhaustive, authoritative, or a guarantee of current or future funding opportunities.

This report is intended for informational and planning purposes only. It does not replace project-specific engineering evaluation, legal advice, or consultation with funding agencies.

Neither the SSC, Cal OES, its staff, nor any collaborating partners shall be held liable for any losses, damages, or claims arising from reliance on the information contained herein.

Appendix A

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
305 N Mount Shasta Blvd, Mount Shasta, CA, 96067, USA	1941 or Prior	1/1/1905	No	Yes	Yes	No	Yes
635 Pacific Ave, Alameda, CA, 94501, USA	1941 or Prior	1/1/1920	No	Yes	No	No	No
496 E Tulare St, Dinuba, CA, 93618, USA	1941 or Prior	1/1/1922	No	Yes	No	No	Yes
128 Roseburg Pkwy, Weed, CA, 96094, USA	1941 or Prior	1/1/1923	No	Yes	No	No	Yes
3401 S Central Ave, Los Angeles, CA, 90011, USA	1941 or Prior	1/1/1925	No	Yes	No	No	Yes
2760 Lincoln Ave, Altadena, CA, 91001, USA	1941 or Prior	10/9/1925	No	Yes	No	No	No
5902 Dunsmuir Ave, Dunsmuir, CA, 96025, USA	1941 or Prior	4/17/1927	No	Yes	No	No	Yes
11351 Tampa Ave, Porter Ranch, CA, 91326, USA	1941 or Prior	4/23/1927	No	Yes	No	No	Yes
137 N F Street, Exeter, CA 93221	1941 or Prior	1/1/1928	No	Yes	No	No	No
430 E 7th St, Los Angeles, CA, 90014, USA	1941 or Prior	1/1/1928	No	Yes	No	No	Yes
635 N Santa Rosa St, San Luis Obispo, CA 93405	1941 or Prior	1/1/1928	No	No	No	No	No
7545 Mission Blvd, Jurupa Valley, CA, 92509, USA	1941 or Prior	1/1/1930	No	Yes	No	No	No
2144 W Sunset Blvd, Los Angeles, CA, 90026, USA	1941 or Prior	1/1/1930	No	Yes	No	No	Yes
743 Reich St, King City, CA, 93930, USA	1941 or Prior	1/1/1930	No	Yes	No	No	No
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1941 or Prior	1/1/1930	No	Yes	Yes	No	No
1666 Tehama Ave, San Luis Obispo, CA 93401	1941 or Prior	1/1/1930	No	No	No	No	No
12900 Skyline Blvd, Los Gatos, CA, 95033, USA	1941 or Prior	1/1/1931	Yes	Yes	No	No	Yes
118 N Fortuna Blvd, Fortuna, CA, 95540, USA	1941 or Prior	1/1/1932	No	Yes	Yes	No	No
201 Cayucos Dr, Cayucos, CA, 93430, USA	1941 or Prior	1/1/1932	Yes	Yes	No	No	Yes
928 S Gerhart Ave, Commerce, CA, 90022, USA	1941 or Prior	1/1/1932	No	Yes	No	No	Yes
604 Antelope Blvd, Red Bluff, CA, 96080, USA	1941 or Prior	1/1/1933	No	Yes	Yes	No	No
635 N Santa Rosa St, San Luis Obispo, CA, 93405, USA	1941 or Prior	10/13/1933	No	No	No	No	No
785 Mountain Ranch Rd, San Andreas, CA, 95249, USA	1941 or Prior	9/24/1934	No	Yes	No	No	No
2764 Eaton Canyon Dr, Pasadena, CA, 91107, USA	1941 or Prior	10/9/1934	No	Yes	No	No	No
950 W Ranger Ave, Alameda, CA, 94501, USA	1941 or Prior	1/1/1936	No	No	No	No	No
3660 E Mission Rd, Fallbrook, CA, 92028, USA	1941 or Prior	10/1/1936	No	Yes	No	No	No
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1941 or Prior	10/4/1936	No	No	No	No	Yes
22317 Waters Dr, Cedarpines Park, CA, 92322, USA	1941 or Prior	10/5/1936	No	Yes	No	No	No
17021 Elizabeth Lake Rd, Lake Hughes, CA, 93532, USA	1941 or Prior	10/22/1936	No	Yes	No	No	No
4206 Cornell Rd, Agoura Hills, CA, 91301, USA	1941 or Prior	10/24/1936	No	Yes	No	No	Yes
40 W Cleveland Ave, Porterville, CA, 93257, USA	1941 or Prior	1/1/1937	No	Yes	No	No	No
404 8th Ave, San Diego, CA, 92101, USA	1941 or Prior	1/1/1938	No	No	No	No	Yes
810 5th St, Orland, CA, 95963, USA	1941 or Prior	1/1/1938	No	Yes	Yes	No	No
132 S San Jacinto Ave, San Jacinto, CA, 92583, USA	1941 or Prior	1/1/1938	No	Yes	No	No	No
3907 W 54th St, Los Angeles, CA, 90043, USA	1941 or Prior	1/1/1938	No	Yes	No	No	Yes
12006 Hadley St, Whittier, CA, 90601, USA	1941 or Prior	10/17/1938	No	Yes	No	No	No
25801 Piuma Rd, Calabasas, CA, 91302, USA	1941 or Prior	10/24/1938	No	Yes	No	No	Yes
120 S Ellsworth Ave, San Mateo, CA, 94401, USA	1941 or Prior	1/1/1939	Yes	Yes	No	No	Yes
610 11th St, Modesto, CA, 95354, USA	1941 or Prior	5/31/1939	No	Yes	No	No	Yes
4212 Isgrigg St, Dunsmuir, CA 96025, USA	1941 or Prior	4/18/1940	No	Yes	No	No	Yes
29382 Main Street, Castella, CA 96017	1941 or Prior	4/18/1940	No	Yes	No	No	Yes
29372 Main Street, Castella, CA 96017	1941 - 1973	4/18/1940	No	Yes	No	No	Yes
3255 Saturn Ave, Huntington Park, CA, 90255, USA	1941 or Prior	11/15/1940	No	Yes	No	No	No
5366 State Highway 49 N, Mariposa, CA, 95338, USA	1941 or Prior	11/17/1940	No	Yes	Yes	No	No
181 N Main St, Bishop, CA 93514	1941 or Prior	1/1/1941	No	Yes	No	No	No
2011 N Eastern Ave, Los Angeles, CA, 90032, USA	1941 or Prior	1/1/1941	No	Yes	No	No	Yes
1601 S Santa Fe Ave, Los Angeles, CA, 90021, USA	1941 or Prior	1/1/1941	No	Yes	No	No	Yes
12229 W Sunset Blvd, Los Angeles, CA, 90049, USA	1941 or Prior	1/1/1941	No	Yes	No	No	Yes
4050 SW Arizona Blvd, Camp Roberts, CA 93451	1941 - 1973	1/1/1941	No	Yes	No	No	No
2315 Bayview Heights Dr, Los Osos, CA 93402	1941 - 1973	1/1/1941	No	Yes	Yes	No	No
1236 School St, Richvale, CA, 95974, USA	1941 - 1973	1/1/1941	No	Yes	No	No	Yes
14630 Plummer St, Panorama City, CA, 91402, USA	1941 - 1973	4/23/1941	No	Yes	No	No	Yes
1930 Shell Ave, Venice, CA, 90291, USA	1941 - 1973	1/1/1942	No	Yes	No	No	Yes
18030 S Vermont Ave, Gardena, CA, 90248, USA	1941 - 1973	1/1/1942	No	Yes	No	No	Yes
288 N Shore Blvd, Kings Beach, CA, 96143, USA	1941 - 1973	1/1/1942	No	Yes	No	No	Yes
7225 N. Rosemead Blvd. San Gabriel, CA 91775	1941 - 1973	1/1/1942	No	Yes	No	No	Yes
1501 Picardy Dr, Stockton, CA, 95203, USA	1941 - 1973	5/13/1942	No	Yes	No	No	No
San Joaquin Building 962, San Luis Obispo, CA 93405	1941 - 1973	10/16/1942	No	Yes	No	No	No
24592 Viejas Grade Rd, Descanso, CA, 91916, USA	1941 - 1973	1/1/1943	No	Yes	No	No	No
1090 Veteran Ave, Los Angeles, CA, 90024, USA	1941 - 1973	1/1/1943	No	Yes	No	No	Yes
101 Meiss Lake Rd, Macdoel, CA, 96058, USA	1941 - 1973	1/1/1944	No	Yes	No	No	No
5840 Horseshoe Bar Rd, Loomis, CA, 95650, USA	1941 - 1973	1/1/1945	No	Yes	No	No	No
2367 Campbell St, Durham, CA, 95938, USA	1941 - 1973	1/1/1945	No	Yes	No	No	No
27330 Highway 78, Julian, CA, 92036, USA	1941 - 1973	1/1/1946	No	Yes	No	No	Yes
8215 Rainbow Heights Rd, Fallbrook, CA, 92028, USA	1941 - 1973	1/1/1946	No	No	Yes	No	Yes
2315 Charles St, Hughson, CA, 95326, USA	1941 - 1973	1/1/1947	No	Yes	No	No	Yes
1834 Pleasant Valley Rd, Placerville, CA, 95667, USA	1941 - 1973	1/1/1947	No	No	No	No	Yes
13871 State Highway 99 N, Chico, CA, 95973	1941 - 1973	1/1/1947	No	Yes	No	No	No
5946 Kauffman Ave, Temple City, CA, 91780, USA	1941 - 1973	1/1/1947	No	Yes	No	No	Yes
124 E I St, Wilmington, CA, 90744, USA	1941 - 1973	1/1/1948	No	Yes	No	No	Yes
107 S Beverly Glen Blvd, Los Angeles, CA, 90024, USA	1941 - 1973	1/1/1948	No	Yes	No	No	Yes
2990 CA-132, La Grange, CA, 95329, USA	1941 - 1973	1/1/1948	No	Yes	No	No	No
13326 Stevens Canyon Road, Cupertino, CA 95014	1941 - 1973	1/1/1948	No	Yes	No	No	No
8900 Emerson Ave, Los Angeles, CA, 90045, USA	1941 - 1973	4/23/1948	No	Yes	No	No	Yes
25627 Auberry Rd, Clovis, CA, 93619, USA	1941 - 1973	9/24/1948	No	Yes	No	Yes	
210 S Academy Ave, Sanger, CA, 93657, USA	1941 - 1973	9/24/1948	No	Yes	No	No	No
14023 Hwy 16, Brooks, CA, 95606, USA	1941 - 1973	9/30/1948	No	Yes	No	No	No
21207 Norwalk Blvd, Hawaiian Gardens, CA 90716	1941 - 1973	10/17/1948	No	Yes	No	No	No
4264 Martin Luther King Junior Boulevard, Lynwood, California 90262	1941 - 1973	11/13/1948	No	Yes	No	No	No
1819 W 7th St, Los Angeles, CA, 90057, USA	1941 - 1973	1/1/1949	No	Yes	No	No	Yes
5921 N Figueroa St, Los Angeles, CA, 90042, USA	1941 - 1973	1/1/1949	No	Yes	No	No	Yes
1556 S Robertson Blvd, Los Angeles, CA, 90035, USA	1941 - 1973	1/1/1949	No	Yes	No	No	Yes

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
5320 Tujunga Ave, North Hollywood, CA, 91601, USA	1941 - 1973	1/1/1949	No	Yes	No	No	Yes
4711 Voltaire St, San Diego, CA, 92107, USA	1941 - 1973	1/1/1949	Yes	No	No	No	Yes
33 Lake Sherwood Dr, Thousand Oaks, CA, 91361, USA	1941 - 1973	1/1/1949	No	Yes	No	No	No
23000 Highway 20, Fort Bragg, CA, 95437, USA	1941 - 1973	1/1/1949	No	Yes	No	No	Yes
923 Patricks Point Dr, Trinidad, CA, 95570, USA	1941 - 1973	1/1/1949	No	Yes	Yes	No	No
525 E Citrus Ave, Redlands, CA 92373	1941 - 1973	1/1/1949	No	Yes	No	No	Yes
510 Bridge St, Bieber, CA, 96009, USA	1941 - 1973	1/1/1949	No	Yes	No	No	No
70578 Parkfield Coalinga Rd, San Miguel, CA, 93451, USA	1941 - 1973	9/24/1949	Yes	Yes	No	Yes	
23087 Tollhouse Rd, Clovis, CA, 93619, USA	1941 - 1973	9/24/1949	No	Yes	No	No	No
1587 CA-78, Julian, CA, 92036, USA	1941 - 1973	1/1/1950	No	Yes	No	No	No
1575 Sutter Ave, San Luis Obispo, CA 93405	1941 - 1973	1/1/1950	No	Yes	No	No	No
1962 E Cesar E Chavez Ave, Los Angeles, CA, 90033, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
7777 Foothill Blvd, Tujunga, CA, 91042, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
2950 W Via Acosta, Montebello, CA, 90640, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
3034 Sacramento St, Placerville, CA, 95667, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
466 S La Luna Ave, Ojai, CA, 93023, USA	1941 - 1973	1/1/1950	No	Yes	No	No	No
513 Church St, Piru, CA, 93040, USA	1941 - 1973	1/1/1950	No	Yes	No	No	No
525 Monterey St, Soledad, CA, 93960, USA	1941 - 1973	1/1/1950	No	Yes	No	Yes	
3207 Cogswell Rd, El Monte, CA, 91732, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
11645 Atwood Rd, Auburn, CA, 95603, USA	1941 - 1973	1/1/1950	No	Yes	No	No	No
15905 Red Bank Rd, Red Bluff, CA, 96080, USA	1941 - 1973	1/1/1950	No	Yes	No	No	Yes
210 W San Jacinto Ave, Perris, CA, 92570, USA	1941 - 1973	1/1/1950	No	Yes	Yes	Yes	
45656 Old Stage Rd, Posey, CA, 93260, USA	1941 - 1973	4/21/1950	No	Yes	No	No	No
108 N Fremont Ave, Los Angeles, CA, 90012, USA	1941 - 1973	4/23/1950	No	Yes	No	No	Yes
2245 Jamacha Rd, El Cajon, CA, 92019, USA	1941 - 1973	9/26/1950	No	Yes	No	No	Yes
11555 Old Oregon Trail, Redding, CA 96049	1941 or Prior	10/2/1950	No	Yes	No	No	Yes
210 W San Jacinto Ave, Perris, CA, 92570, USA	1941 - 1973	10/24/1950	No	Yes	No	No	No
7643 Santa Monica Blvd, West Hollywood, CA, 90046, USA	1941 - 1973	10/24/1950	No	Yes	No	No	Yes
56560 CA-371, Anza, CA, 92539, USA	1941 - 1973	10/29/1950	No	Yes	No	No	Yes
5112 Peck Rd, El Monte, CA, 91732, USA	1941 - 1973	10/31/1950	No	Yes	No	No	Yes
3161 East Imperial Highway, Lynwood, California 90262	1941 - 1973	11/13/1950	No	Yes	No	No	No
3161 East Imperial Highway, Lynwood, California 90262	1941 - 1973	11/15/1950	No	Yes	No	No	No
4867 Southern Ave, South Gate, CA, 90280, USA	1941 - 1973	11/15/1950	No	Yes	No	No	No
3661 7th Ave, Los Angeles, CA, 90018, USA	1941 - 1973	1/1/1951	No	Yes	No	No	Yes
3111 Cahuenga Blvd W, Los Angeles, CA, 90068, USA	1941 - 1973	1/1/1951	No	Yes	No	No	Yes
151 Lake Merced Blvd., Daly City, CA	1941 - 1973	1/1/1951	No	Yes	No	No	No
65789 Bradley Rd, Bradley, CA, 93426, USA	1941 - 1973	1/1/1951	No	Yes	No	No	No
5300 Coalinga Rd, Paicines, CA, 95043, USA	1941 - 1973	1/1/1951	No	Yes	No	No	Yes
15670 Monterey Rd, Morgan Hill, CA, 95037, USA	1941 - 1973	1/1/1951	No	Yes	Yes	No	Yes
4731 Pedro Hill Rd, Pilot Hill, CA, 95664, USA	1941 - 1973	1/1/1951	No	Yes	No	No	No
14000 Hwy 12, Glen Ellen, CA, 95442, USA	1941 - 1973	1/1/1951	No	Yes	No	No	Yes
11200 Speegle St, Castroville, CA, 95012, USA270	1941 - 1973	5/24/1951	No	Yes	No	No	Yes
4091 Millerton Rd, Friant, CA, 93626, USA	1941 - 1973	9/24/1951	No	Yes	No	No	No
4526 Ramsdell Ave, La Crescenta, CA, 91214, USA	1941 - 1973	10/9/1951	No	Yes	No	No	No
67820 Jolon Rd, Lockwood, CA, 93932, USA	1941 - 1973	1/1/1952	No	Yes	No	No	No
25130 State Route 94, Potrero, CA, 91963, USA	1941 or Prior	1/1/1952	No	Yes	No	No	No
320 Paul Scannell Dr, San Mateo, CA, 94402	1941 - 1973	6/13/1952	No	Yes	No	No	No
77251 Covelo Rd, Covelo, CA, 95428, USA	1941 - 1973	10/16/1952	No	Yes	No	No	No
12 Crest Rd W, Rolling Hills, CA, 90274, USA	1941 - 1973	10/30/1952	No	Yes	No	No	No
9319 E. Valley Blvd. Rosemead, CA 91770	1941 - 1973	10/31/1952	No	Yes	No	No	Yes
12050 Balboa Blvd, Granada Hills, CA, 91344, USA	1941 - 1973	1/1/1953	No	Yes	No	No	Yes
1606 Hillhurst Ave, Los Angeles, CA, 90027, USA	1941 - 1973	1/1/1953	No	Yes	No	No	Yes
1972 Chicago St, San Diego, CA, 92110, USA	1941 - 1973	1/1/1953	No	No	No	No	Yes
17475 Fredson Rd, Healdsburg, CA, 95448, USA	1941 - 1973	1/1/1953	No	Yes	No	No	No
19650 Santa Cruz Hwy, Los Gatos, CA, 95033, USA	1941 - 1973	1/1/1953	No	Yes	Yes	No	No
18365 Cajon Ct, San Bernardino, CA, 92407, USA	1941 - 1973	1/1/1953	No	Yes	No	No	No
9548 Flower St, Bellflower, CA, 90706, USA	1941 - 1973	1/1/1953	No	Yes	No	No	No
410 W Graham Ave, Lake Elsinore, CA, 92530, USA	1941 - 1973	1/1/1953	No	Yes	No	No	Yes
1335 S Olive St, Los Angeles, CA, 90015, USA	1941 - 1973	1/1/1954	No	Yes	No	No	Yes
2850 54th St, San Diego, CA, 92105, USA	1941 - 1973	1/1/1954	No	Yes	No	No	Yes
2521 El Molino Ave, Altadena, CA, 91001, USA	1941 - 1973	1/1/1954	No	Yes	No	No	No
6140 Parkhill Rd, Santa Margarita, CA, 93453, USA	1941 - 1973	1/1/1954	No	Yes	No	No	Yes
23322 Avenue of the Giants St, Myers Flat, CA, 95554, USA	1941 - 1973	1/1/1954	No	Yes	Yes	No	No
14800 Bowman Rd, Cottonwood, CA, 96022, USA	1941 - 1973	1/1/1954	No	Yes	No	No	No
12960 Toomes Camp Rd, Paskenta, CA, 96080, USA	1941 - 1973	10/19/1954	No	Yes	Yes	No	No
23720 Malibu Rd, Malibu, CA, 90265, USA	1941 - 1973	10/24/1954	No	Yes	No	No	Yes
708 N. San Antonio Ave. Pomona, CA 91767	1941 - 1973	11/25/1954	No	Yes	No	No	No
1701 Crenshaw Blvd, Torrance, CA, 90501, USA	1941 - 1973	1/1/1955	No	Yes	No	No	Yes
5205 Calle Mayor, Torrance, CA 90505	1941 - 1973	1/1/1955	No	Yes	No	No	Yes
5064 Clairemont Dr, San Diego, CA, 92117, USA	1941 - 1973	1/1/1955	No	No	No	No	Yes
25820 Airline Hwy, Paicines, CA, 95043, USA	1941 - 1973	1/1/1955	No	Yes	No	No	No
5398 E Pozo Rd, Santa Margarita, CA, 93453, USA	1941 - 1973	1/1/1955	No	Yes	No	No	No
3615 Santa Anita Ave, El Monte, CA, 91731, USA	1941 - 1973	1/1/1955	No	Yes	No	No	Yes
28330 Mercedes St, Temecula, CA, 92590, USA	1941 - 1973	1/1/1955	No	Yes	No	No	No
1116 E 1st St, Stockton, CA, 95206, USA	1941 - 1973	5/13/1955	No	Yes	No	No	No
25150 Foresthill Rd, Foresthill, CA, 95631, USA	1941 - 1973	10/2/1955	No	Yes	No	No	Yes
1729 Foothill Blvd, La Canada Flintridge, CA, 91011, USA	1941 - 1973	10/9/1955	No	Yes	No	No	No
352 Foothill Blvd, La Canada Flintridge, CA, 91011, USA	1941 - 1973	10/9/1955	No	Yes	No	No	No
401 S Topanga Canyon Blvd, Topanga, CA, 90290, USA	1941 - 1973	10/24/1955	No	Yes	No	No	Yes
2327 S. Saybrook Ave. Commerce, CA 90040	1941 - 1973	10/28/1955	No	Yes	No	No	Yes
137 W Redondo Beach Blvd, Gardena, CA, 90248, USA	1941 - 1973	10/30/1955	No	Yes	No	No	No
19691 Ridge Rd, Red Bluff, CA, 96080, USA	1941 or Prior	1/1/1956	No	No	No	No	No
10435 S Sepulveda Blvd, Los Angeles, CA, 90045, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes
7921 Woodley Ave, Van Nuys, CA, 91406, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes
14430 Polk St, Sylmar, CA, 91342, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
6430 Pony Express Trail, Pollock Pines, CA, 95726, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes
5545 S Libby Rd, Paradise, CA, 95969, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes
6320 Pine Ave, Bell, CA, 90201, USA	1941 - 1973	1/1/1956	No	Yes	No	No	Yes
10630 S. Mills Ave. Whittier, CA 60604	1941 - 1973	10/17/1956	No	Yes	No	No	No
38318 9th St E, Palmdale, CA, 93550, USA	1941 - 1973	10/29/1956	No	Yes	No	No	No
1980 W. Orange Grove Ave. Pomona, CA 91768	1941 - 1973	11/25/1956	No	Yes	No	No	No
2701 Cipriani Blvd, Belmont, CA, 94002, USA	1941 - 1973	1/1/1957	Yes	Yes	No	No	Yes
944 Cesar E Chavez Pkwy, San Diego, CA, 92113, USA	1941 - 1973	1/1/1957	Yes	No	No	No	Yes
1010 CA-16, Williams, CA, 95987, USA	1941 - 1973	1/1/1957	No	Yes	No	No	No
33333 Alta Forestry Rd, Dutch Flat, CA, 95714, USA	1941 - 1973	1/1/1957	No	Yes	No	No	No
11567 Bryant Rd. El Monte, CA 91731	1941 - 1973	1/1/1957	No	Yes	No	No	Yes
19076 Tyler Foote Rd, Nevada City, CA, 95959, USA	1941 - 1973	10/2/1957	No	Yes	No	No	No
2555 Shell Beach Rd, Pismo Beach, CA, 93449, USA	1941 - 1973	10/14/1957	Yes	Yes	No	No	No
5030 W Avenue L14, Quartz Hill, CA, 93536, USA	1941 - 1973	10/24/1957	No	Yes	No	No	No
4710 W Stetson Ave, Hemet, CA, 92545, USA	1941 - 1973	10/29/1957	No	No	No	No	No
25517 Narbonne Ave, Lomita, CA, 90717, USA	1941 - 1973	10/30/1957	No	Yes	No	No	No
6124 Palos Verdes Dr S, Rancho Palos Verdes, CA, 90275, USA	1941 - 1973	10/30/1957	No	Yes	Yes	No	No
945 Avalon Canyon Rd, Avalon, CA, 90704, USA	1941 - 1973	10/30/1957	No	Yes	No	No	No
12151 Crenshaw Blvd, Hawthorne, CA, 90250, USA	1941 - 1973	10/30/1957	No	Yes	No	No	No
10701 South Crenshaw Boulevard, Inglewood, California 90303	1941 - 1973	11/13/1957	No	Yes	No	No	No
11736 Telegraph Rd, Santa Fe Springs, CA, 90670, USA	1941 - 1973	1/1/1958	No	Yes	No	No	Yes
4570 Hollister Ave, Santa Barbara, CA, 93110, USA	1941 - 1973	1/1/1958	No	Yes	No	No	No
3036 Fletcher Dr, Los Angeles, CA, 90065, USA	1941 - 1973	1/1/1958	No	Yes	No	No	Yes
3880 Kearny Villa Rd, San Diego, CA, 92123, USA	1941 - 1973	1/1/1958	No	Yes	No	No	Yes
5838 Telegraph Rd, Ventura, CA, 93003, USA	1941 - 1973	1/1/1958	No	Yes	No	No	Yes
9711 Flinn Springs Rd, El Cajon, CA 92021	1941 - 1973	1/1/1958	No	Yes	No	No	Yes
1475 S State St, Ukiah, CA, 95482, USA	1941 - 1973	1/1/1958	No	Yes	No	No	No
46101 Highway 101, Laytonville, CA, 95454, USA	1941 - 1973	9/1/1958	No	Yes	No	No	No
25910 Long Barn Rd, Long Barn, CA, 95335, USA	1941 - 1973	9/8/1958	No	Yes	No	No	Yes
6640 Steiffer Rd, Magalia, CA, 95954, USA	1941 - 1973	10/3/1958	No	No	No	No	No
10106 Combie Rd, Auburn, CA, 95602, USA	1941 - 1973	10/8/1958	No	Yes	No	No	No
15800 CA-20, Fort Bragg, CA, 95437, USA	1941 - 1973	10/16/1958	No	Yes	Yes	No	Yes
4020 Candlewood St, Lakewood, CA 90712	1941 - 1973	10/17/1958	No	Yes	No	No	No
7300 S. Paramount Blvd. Pico Rivera, CA 90660	1941 - 1973	10/17/1958	No	Yes	No	No	No
24875 Railroad Ave, Newhall, CA, 91321, USA	1941 - 1973	10/18/1958	No	Yes	No	No	No
18915 S Santa Fe Ave, Compton, CA, 90221, USA	1941 - 1973	10/30/1958	No	Yes	No	No	No
340 Palos Verdes Dr W, Palos Verdes Estates, CA, 90274, USA	1941 - 1973	10/30/1958	No	Yes	No	No	No
540 Pier Ave, Hermosa Beach, CA, 90254, USA	1941 - 1973	10/30/1958	No	Yes	No	No	No
2030 W 135th St, Gardena, CA, 90249, USA	1941 - 1973	10/30/1958	No	Yes	No	No	No
2040 Sumner Ave, Claremont, CA, 91711, USA	1941 - 1973	11/25/1958	No	Yes	No	No	No
807 W. Cypress St. Covina, CA 91723	1941 - 1973	11/25/1958	No	Yes	No	No	No
11345 Pleasanton Sunol Rd, Sunol, CA, 94586, USA	1941 - 1973	1/1/1959	No	Yes	No	No	No
2021 Colorado Blvd, Los Angeles, CA, 90041, USA	1941 - 1973	1/1/1959	No	Yes	No	No	Yes
10556 W Pico Blvd, Los Angeles, CA, 90064, USA	1941 - 1973	1/1/1959	No	Yes	No	No	Yes
10010 International Rd, Los Angeles, CA, 90045, USA	1941 - 1973	1/1/1959	No	Yes	No	No	Yes
2265 Coronado Ave, San Diego, CA, 92154, USA	1941 - 1973	1/1/1959	No	Yes	No	No	Yes
2736 W Orange Ave, Anaheim, CA, 92804, USA	1941 - 1973	1/1/1959	No	Yes	No	No	No
Pit River Rd, Canby, CA, 96015, USA	1941 - 1973	1/1/1959	No	Yes	No	No	No
4454 Berryessa Knoxville Rd, Napa, CA, 94558, USA	1941 - 1973	1/1/1959	No	Yes	No	No	No
110 W Sonora St, Stockton, CA, 95203, USA	1941 - 1973	5/13/1959	No	Yes	Yes	No	No
616 Edgemar Ave, Pacifica, CA, 94044, USA	1941 - 1973	5/21/1959	No	Yes	No	No	No
140 S. Second Ave. Industry, CA 91746-2413	1941 - 1973	10/17/1959	No	Yes	No	No	No
2691 S. Turnbull Canyon Rd. Hacienda Heights, CA 91745-5135	1941 - 1973	10/17/1959	No	Yes	No	No	No
5720 Gardendale St, South Gate, CA, 90280, USA	1941 - 1973	11/15/1959	No	Yes	No	No	No
2401 Encinal Ave, Alameda, CA, 94501, USA	1941 - 1973	1/1/1960	No	Yes	No	No	No
8634 Dice Rd, Santa Fe Springs, CA, 90670, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
23658 Avenue 95, Terra Bella, CA, 93270, USA	1941 - 1973	1/1/1960	No	Yes	No	No	No
15345 San Fernando Mission Blvd, Mission Hills, CA, 91345, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
19059 Ventura Blvd, Tarzana, CA, 91356, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
13035 Van Nuys Blvd, Pacoima, CA, 91331, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
13275 US Highway 50, Kyburz, CA, 95720, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
23496 Miller Canyon Rd., Hesperia, CA 92345	1941 - 1973	1/1/1960	Yes	Yes	No	No	No
26321 Sand Canyon Rd, Canyon Country, CA, 91387, USA	1941 - 1973	1/1/1960	No	Yes	No	No	No
2990 CA-132, La Grange, CA, 95329, USA	1941 - 1973	1/1/1960	No	Yes	No	No	Yes
30816 Crag View Dr, Dunsmuir, CA 96025, USA	1941 - 1973	4/18/1960	No	Yes	No	No	Yes
191 Edgemont Dr, Daly City, CA, 94015, USA	1941 - 1973	5/21/1960	No	Yes	No	No	No
1200 Pescadero Creek Rd, Pescadero, CA, 94060, USA	1941 - 1973	6/13/1960	No	Yes	No	No	No
12110 E Adoree St, Norwalk, CA, 90650, USA	1941 - 1973	9/30/1960	No	Yes	No	No	No
11317 Alondra Blvd. Norwalk, CA 90650	1941 - 1973	10/17/1960	No	Yes	No	No	No
850 W. La Habra Blvd. La Habra, CA 90631	1941 - 1973	10/17/1960	No	Yes	No	No	No
8905 E Avenue U, Littlerock, CA, 93543, USA	1941 - 1973	10/29/1960	No	Yes	No	No	No
5323 W Rosecrans Ave, Hawthorne, CA, 90250, USA	1941 - 1973	10/30/1960	No	Yes	No	No	No
2401 W Pico Blvd, Los Angeles, CA, 90006, USA	1941 - 1973	1/1/1961	No	Yes	No	No	Yes
4305 Vineland Ave, North Hollywood, CA, 91602, USA	1974 -1993	1/1/1961	No	Yes	No	No	Yes
6751 Louise Ave, Van Nuys, CA, 91406, USA	1941 - 1973	1/1/1961	No	Yes	No	No	Yes
18143 Parthenia St, Northridge, CA, 91325, USA	1941 - 1973	1/1/1961	No	Yes	No	No	Yes
824 Clark Ave, Yuba City, CA, 95991, USA	1941 - 1973	1/1/1961	No	Yes	No	No	No
484 Briarwood Rd, San Diego, CA, 92114, USA	1941 - 1973	1/1/1961	No	Yes	No	No	Yes
2324 Stirrup Rd, Borrego Springs, CA 92004	1941 - 1973	1/1/1961	No	Yes	No	No	Yes
555 E Avenida de los Arboles, Thousand Oaks, CA, 91360, USA	1941 - 1973	1/1/1961	No	Yes	No	No	No
2221 Garden Rd, Monterey, CA, 93940, USA	1941 - 1973	1/1/1961	No	No	No	No	No
6059 Highway 9, Felton, CA, 95018, USA	1941 - 1973	1/1/1961	No	Yes	Yes	No	No
7930 Sherwood Blvd, Los Molinos, CA, 96055, USA	1941 - 1973	1/1/1961	No	Yes	No	No	No
30502 Plum Creek Rd, Paynes Creek, CA, 96075, USA	1941 - 1973	1/1/1961	No	No	No	No	No
9209 E. Slauson Ave. Pico Rivera, CA 91744	1941 - 1973	10/17/1961	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
6421 Turnergrove Dr, Lakewood, CA 90713	1941 - 1973	10/17/1961	No	Yes	No	No	No
1059 N. White Ave. Pomona, CA 91768	1941 - 1973	11/25/1961	No	Yes	No	No	No
605 N. Angeleno Ave. Azusa, CA 91702	1941 - 1973	11/25/1961	No	Yes	No	No	No
1577 E. Cypress St. Covina, CA 91724	1941 - 1973	11/25/1961	No	Yes	No	No	No
21800 Marilla St, Chatsworth, CA, 91311, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
8021 Mulholland Dr, Los Angeles, CA, 90046, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
1414 W 25th St, Los Angeles, CA, 90007, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
13200 Burbank Blvd, Valley Glen, CA, 91401, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
8349 Winnetka Ave, Winnetka, CA, 91306, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
6345 Fallbrook Ave, Woodland Hills, CA, 91367, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
23004 Roscoe Blvd, West Hills, CA, 91304, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
25135 Robinson Way, Torrance, CA, 90505, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
5425 W Lake Blvd, Homewood, CA, 96141, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
240 Carnelian Bay Rd, Carnelian Bay, CA, 96140, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
41 N Seaward Ave, Ventura, CA, 93001, USA	1941 - 1973	1/1/1962	No	Yes	No	No	Yes
500 E Broadway, Anaheim, CA, 92805, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
22670 Highway 26, West Point, CA, 95255, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
11460 Santa Gertrudes Ave, Whittier, CA, 90604, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
44056 Mattole Rd, Petrolia, CA, 95558, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
2784 S Round Valley Rd, Bishop, CA, 93514, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
14638 Bradley Henley Rd, Hombrook, CA, 96044, USA	1941 - 1973	1/1/1962	No	Yes	No	No	No
3305 Kemper St, San Diego, CA, 92110, USA	1941 - 1973	5/29/1962	No	Yes	No	No	Yes
501 Stetson Street, Moss Beach, CA 94038	1941 - 1973	6/12/1962	No	Yes	No	No	No
Soledad Canyon Rd, Canyon Country, CA, 91351, USA	1941 - 1973	10/4/1962	No	Yes	No	No	No
10021 Scott Ave. Whittier, CA 90603	1941 - 1973	10/17/1962	No	Yes	No	No	No
650 E Gladstone St, Glendora, CA, 91740, USA	1941 - 1973	11/25/1962	No	Yes	No	No	No
925 E. Lexington Ave. Pomona, CA 91766	1941 - 1973	11/25/1962	No	Yes	No	No	No
15517 Carmenita Rd, Santa Fe Springs, CA, 90670, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
17281 W Sunset Blvd, Pacific Palisades, CA, 90272, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
11505 W Olympic Blvd, Los Angeles, CA, 90064, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
14145 Mulholland Dr, Beverly Hills, CA, 90210, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
20225 Devonshire St, Chatsworth, CA, 91311, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
12520 Mulholland Dr, Beverly Hills, CA, 90210, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
600 N Montebello Blvd, Montebello, CA, 90640, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
8041 Hwy 89, Tahoma, CA, 96142, USA	1941 - 1973	1/1/1963	No	Yes	No	No	Yes
5440 Longview Ln, Georgetown, CA, 95634, USA	1941 - 1973	1/1/1963	No	No	No	No	No
2781 S Round Valley Rd, Bishop, CA, 93514, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
1400 Alder Camp Rd, Klamath, CA, 95548, USA	1941 - 1973	1/1/1963	No	No	Yes	No	No
5660 Mother Lode Dr, Placerville, CA, 95667, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
33333 Alta Forestry Rd, Dutch Flat, CA, 95714, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
13760 Lincoln Way, Auburn, CA, 95603, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
13760 Lincoln Way, Auburn, CA, 95603, USA	1941 - 1973	1/1/1963	No	Yes	No	No	No
6565 Cowles Mountain Blvd, San Diego, CA, 92119, USA	1941 - 1973	5/29/1963	No	No	No	No	Yes
6185 Elwood Rd, Sanger, CA, 93657, USA	1941 - 1973	9/24/1963	No	Yes	No	No	No
13044 Highway 29, Lower Lake, CA, 95457, USA	1941 - 1973	10/2/1963	No	No	No	No	No
13760 Lincoln Way, Auburn, CA, 95603, USA	1941 - 1973	10/3/1963	No	Yes	No	No	No
31250 Hilltop Blvd, Running Springs, CA 92382	1941 - 1973	10/5/1963	No	Yes	No	No	No
11972 State Highway 70, Oroville, CA, 95965, USA	1941 - 1973	10/7/1963	No	Yes	No	No	No
921 S. Stimson Ave. Industry, CA 91745-1687	1941 - 1973	10/17/1963	No	Yes	No	No	No
520 S. Harbor Blvd. La Habra, CA 90631	1941 - 1973	10/17/1963	No	Yes	No	No	No
590 S. Park Ave. Pomona, CA 91766	1941 - 1973	11/25/1963	No	No	No	No	No
767 Birch St, Paradise, CA, 95969, USA	1941 - 1973	1/1/1964	No	Yes	No	No	No
3974 Goldfinch St, San Diego, CA, 92103, USA	1941 - 1973	1/1/1964	Yes	No	No	No	Yes
2190 Comstock St, San Diego, CA, 92111, USA	1941 - 1973	1/1/1964	No	Yes	No	No	Yes
8303 Telephone Rd, Ventura, CA, 93004, USA	1941 - 1973	1/1/1964	No	Yes	No	No	Yes
25101 W Morton Ave, Tranquility, CA, 93668, USA	1941 - 1973	1/1/1964	No	Yes	No	No	No
7105 Airway Ave, Yucca Valley, CA, 92284, USA	1941 - 1973	1/1/1964	No	Yes	No	No	No
2420 Airport Rd, Fortuna, CA, 95540, USA	1941 - 1973	1/1/1964	No	Yes	No	No	No
3337 Road 307, Elk Creek, CA 95939	1941 - 1973	1/1/1964	No	Yes	No	No	No
1280 Laurel Ln, San Luis Obispo, CA 93401	1941 - 1973	1/1/1964	No	No	No		
3970 Carbon Canyon Rd, Malibu, CA, 90265, USA	1941 - 1973	1/1/1964	No	Yes	No	No	Yes
1690 Garden St, Redlands, CA, 92373, USA	1941 - 1973	1/1/1964	No	Yes	No	No	Yes
2203 CA-140, Catheys Valley, CA 95306	1941 - 1973	1/1/1964	No	Yes	No	No	No
50 W Center St, Rio Dell, CA, 95562, USA	1941 - 1973	1/26/1964	Yes	Yes	Yes	No	Yes
655 Lohrman Ln, Petaluma, CA, 94952, USA	1941 - 1973	10/1/1964	No	Yes	No	No	No
11425 Conservation Rd, Nevada City, CA, 95959, USA	1941 - 1973	10/7/1964	No	No	No	No	No
275 Cypress Mountain Dr, Paso Robles, CA, 93446, USA	1941 - 1973	10/26/1964	No	Yes	No	No	Yes
1650 W 162nd St, Gardena, CA, 90247, USA	1941 - 1973	10/30/1964	No	Yes	No	No	No
280 E. Bonita Ave. Pomona, CA 91767	1941 - 1973	11/25/1964	No	Yes	No	No	No
7164 7th Ave, Tahoma, CA, 96142, USA	1941 - 1973	1/1/1965	No	No	No	No	Yes
2222 E Ball Rd, Anaheim, CA, 92806, USA	1941 - 1973	1/1/1965	No	Yes	No	No	No
1392 Nees Ave, Clovis, CA, 93611, USA	1941 - 1973	1/1/1965	No	Yes	No	No	No
3265 Tapo St, Simi Valley, CA, 93063, USA	1941 - 1973	1/1/1965	No	Yes	No	No	No
69310 N Highway 101, Leggett, CA, 95585, USA	1941 - 1973	1/1/1965	No	Yes	No		
1025 US Highway 101 N, Crescent City, CA, 95531, USA	1941 - 1973	1/1/1965	No	Yes	No	No	No
25900 Big Rock Creek Rd, Valyermo, CA 93563	1941 - 1973	1/1/1965	No	No	No	No	No
14041 Park Ave, Jamestown, CA, 95327, USA	1941 - 1973	9/8/1965	No	Yes	No	No	Yes
11645 Atwood Rd, Auburn, CA, 95603, USA	1941 or Prior	10/1/1965	No	Yes	No	No	No
19545 Alderpoint Rd, Alderpoint, CA, 95511, USA	1941 - 1973	10/1/1965	No	Yes	No	No	No
26488 Avenue 140, Porterville, CA, 93257, USA	1941 - 1973	10/7/1965	No	Yes	No	No	Yes
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1941 - 1973	10/7/1965	No	No	No	No	No
1809 Fairlane Rd, Yreka, CA, 96097, USA	1941 - 1973	10/14/1965	No	Yes	No	No	No
15336 E. Elliott Ave. La Puente, CA 91744-2710	1941 - 1973	10/17/1965	No	Yes	No	No	No
520 Amelia Ave, Glendora, CA, 91741, USA	1941 - 1973	11/25/1965	No	Yes	No	No	No
231 W. Mountain View Ave. Glendora, CA 91740	1941 - 1973	11/25/1965	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
1105 Highland Ave. Duarte, CA 91010	1941 - 1973	11/25/1965	No	Yes	No	No	No
99 Centennial St, Los Alamos, CA, 93440, USA42035	1941 - 1973	1/1/1966	No	Yes	No	No	No
159 Observation Dr, Tahoe City, CA, 96145, USA	1941 - 1973	1/1/1966	No	No	No	No	Yes
11700 Merrell Rd, Groveland, CA, 95321, USA	1941 - 1973	1/1/1966	No	Yes	Yes	No	No
12604 River Rd, Guerneville, CA, 95446, USA	1941 - 1973	1/1/1966	No	Yes	No	No	No
22 Walnut Ave, Oroville, CA, 95966, USA	1941 - 1973	1/1/1966	No	Yes	No	No	No
180 Terwer Valley Rd, Klamath, CA, 95548, USAw	1941 - 1973	1/1/1966	No	Yes	No	No	No
22805 Mount Hamilton Rd, Mt Hamilton, CA, 95140	1941 - 1973	1/1/1966	No	Yes	No	No	Yes
2517 Highway 4, Arnold, CA, 95223, USA	1941 - 1973	9/24/1966	No	Yes	No	No	No
9946 Marysville Rd, Dobbins, CA, 95935, USA	1941 - 1973	10/5/1966	No	Yes	No	No	No
23310 Lake Manor Dr, Chatsworth, CA, 91311, USA	1941 - 1973	10/10/1966	No	Yes	No	No	No
300 CA-97, Weed, CA, 96094, USA	1941 - 1973	10/14/1966	No	Yes	No	No	No
11425 Conservation Rd, Nevada City, CA, 95959, USA	1941 - 1973	10/15/1966	No	No	No	No	No
7733 Greenleaf Ave. Whittier, CA 90602	1941 - 1973	10/17/1966	No	Yes	No	No	No
7521 Somerset Blvd, Paramount, CA 90723	1941 - 1973	10/17/1966	No	Yes	No	No	No
27223 Henry Mayo Dr, Valencia, CA, 91355, USA	1941 - 1973	10/18/1966	No	Yes	No	No	No
2049 E 223rd St, Carson, CA, 90810, USA	1941 - 1973	10/30/1966	No	Yes	No	No	No
6901 Frey Way, Goleta, CA, 93117, USA	1941 - 1973	1/1/1967	No	Yes	No	No	No
6901 Frey Way, Goleta, CA, 93117, USA	1941 - 1973	1/1/1967	No	Yes	No	No	
15405 W Sunset Blvd, Pacific Palisades, CA, 90272, USA	1941 - 1973	1/1/1967	No	Yes	No	No	Yes
10331 Loch Lomond Rd, Loch Lomond, CA 95461	1941 - 1973	1/1/1967	No	No	No	No	No
3940 Del Amo Blvd, Torrance, CA, 90503, USA	1941 - 1973	1/1/1967	No	Yes	No	No	Yes
1392 Nees Ave, Clovis, CA, 93611, USA	1941 - 1973	1/1/1967	No	Yes	No	No	No
5785 Sly Park Rd, Pollock Pines, CA, 95726, USA	1941 - 1973	1/1/1967	No	No	No	No	Yes
10 Robinson Mill Rd, Oroville, CA, 95966, USA	1941 - 1973	1/1/1967	No	Yes	No	No	No
11851 Marsh Creek Rd. Clayton, CA 94517	1941 - 1973	1/1/1967	No	Yes	No	No	No
850 Eel River Camp Road, Redway, CA 95560	1941 - 1973	1/1/1967	No	No	Yes	No	No
434 B St, Biggs, CA, 95917, USA	1941 - 1973	1/1/1967	No	Yes	No	No	No
5525 Pacific Ave, Stockton, CA, 95207, USA	1941 - 1973	5/13/1967	No	Yes	No	No	No
550 E Harding Way, Stockton, CA, 95204, USA	1941 - 1973	5/13/1967	No	Yes	No	No	No
Forest Service Road 5N20, Twain Harte, CA 95383, United States	1941 - 1973	9/25/1967	No	Yes	No	No	No
9127 W Lilac Rd, Escondido, CA, 92026, USA	1941 - 1973	9/26/1967	No	Yes	Yes	No	No
10331 Loch Lomond Rd, Middletown, CA, 95461, USA	1941 - 1973	10/11/1967	No	No	No	No	No
13820 S. La Mirada Blvd. La Mirada, CA 90638	1941 - 1973	10/17/1967	No	Yes	No	No	No
127 W 223rd St, Carson, CA, 90745, USA	1941 - 1973	10/30/1967	No	Yes	No	No	No
810 Centinela Avenue, Inglewood, California 90203	1941 - 1973	11/13/1967	No	Yes	No	No	No
4735 Airport Rd, Paso Robles, CA, 93446, USA	1941 - 1973	1/1/1968	No	Yes	No	No	Yes
400 Yacht St, Wilmington, CA 90744	1941 - 1973	1/1/1968	No	Yes	No	No	Yes
403 Valley Vista Dr, Camarillo, CA, 93010, USA	1941 - 1973	1/1/1968	No	Yes	No	No	No
11600 La Grange Rd, Jamestown, CA, 95327, USA	1941 - 1973	1/1/1968	No	No	No	No	Yes
604 Antelope Blvd, Red Bluff, CA, 96080, USA	1941 - 1973	1/1/1968	No	Yes	No	No	No
10115 E Rush St, S El Monte, CA, 91733, USA	1941 - 1973	1/1/1968	No	Yes	No	No	Yes
433 Main St, Copperopolis, CA, 95228, USA	1941 - 1973	9/25/1968	No	Yes	No	No	No
8723 Elizabeth Lake Rd, Leona Valley, CA, 93551, USA	1941 - 1973	10/10/1968	No	Yes	No	No	No
2300 E 27th St, Signal Hill, CA 90755	1941 - 1973	10/17/1968	No	Yes	No	No	No
24130 Calabasas Rd, Calabasas, CA, 91302, USA	1941 - 1973	10/24/1968	No	Yes	No	No	Yes
1051 S. Grand Ave. Diamond Bar, CA 91765	1941 - 1973	11/25/1968	No	Yes	No	No	No
15546 E. Arrow Hwy. Irwindale, CA 91706	1941 - 1973	11/25/1968	No	Yes	No	No	No
168 W Highway 246, Buellton, CA, 93427, USA	1941 - 1973	1/1/1969	No	Yes	No	No	
9411 Wentworth St, Sunland, CA, 91040, USA	1941 - 1973	1/1/1969	No	Yes	No	No	Yes
1222 1st Ave, San Diego, CA, 92101, USA	1941 - 1973	1/1/1969	No	Yes	No	No	Yes
5810 S Cherry Ave, Fresno, CA, 93706, USA	1941 - 1973	1/1/1969	No	Yes	No	No	No
5855 Chateau Dr, San Diego, CA, 92117, USA	1941 - 1973	1/1/1969	No	Yes	No	No	Yes
140 Spring Rd, Clearlake Oaks, CA, 95423, USA	1941 - 1973	1/1/1969	No	Yes	Yes	No	Yes
9814 Maplewood St, Bellflower, CA 90706	1941 - 1973	1/1/1969	No	Yes	No	No	No
16966 Bernardo Center Dr, San Diego, CA, 92128, USA	1941 - 1973	5/29/1969	No	Yes	No	No	Yes
11972 State Highway 70, Oroville, CA, 95965, USA	1941 - 1973	10/4/1969	No	Yes	No	No	No
20604 Loyalton Dr. Walnut, CA 91789-121	1941 - 1973	10/17/1969	No	No	No	No	No
4475 W El Segundo Blvd, Hawthorne, CA, 90250, USA	1941 - 1973	10/30/1969	No	Yes	No	No	No
2334 Fair St, Chico, CA, 95928, USA	1941 - 1973	1/1/1970	No	Yes	No	No	
2009 S Western Ave, Los Angeles, CA, 90018, USA	1941 - 1973	1/1/1970	No	Yes	No	No	Yes
11500 E Mountain View Ave, Selma, CA, 93662, USA	1941 - 1973	1/1/1970	No	Yes	No	No	No
57 Journey, Aliso Viejo, CA, 92656, USA	1941 - 1973	1/1/1970	No	Yes	No	No	
4600 Cazadero Hwy, Cazadero, CA 95421	1941 - 1973	1/1/1970	No	Yes	No	No	No
10810 No Name Uno, Gilroy, CA 95020	1941 - 1973	1/1/1970	No	Yes	No	No	Yes
3050 Hecker Pass Rd, Gilroy, CA, 95020, USA	1941 - 1973	1/1/1970	No	Yes	No	No	No
11075 US Forestry Rd, Cobb, CA, 95461, USA	1941 - 1973	3/1/1970	Yes	Yes	No	No	No
16925 Mono Vista Rd N, Sonora, CA, 95370, USA	1941 - 1973	9/8/1970	No	Yes	No	No	Yes
13717 E. Artesia Blvd. Cerritos, CA 90703	1941 - 1973	10/17/1970	No	Yes	No	No	No
2600 Greenmeadow Rd, Lakewood, CA 90712	1941 - 1973	10/17/1970	No	Yes	No	No	No
5215 Las Virgenes Rd, Calabasas, CA, 91302, USA	1941 - 1973	10/24/1970	No	Yes	No	No	Yes
31981 Foxfield Dr, Westlake Village, CA, 91361, USA	1941 - 1973	10/24/1970	No	Yes	No	No	Yes
15921 Spunky Canyon Rd, Green Valley, CA, 91390, USA	1941 - 1973	10/29/1970	No	Yes	No	No	No
27413 Palos Verdes Dr E, Rolling Hills Estates, CA, 90275, USA	1941 - 1973	10/30/1970	No	Yes	No	No	No
1511 Hamner Ave, Norco, CA, 92860, USA	1941 - 1973	10/31/1970	No	Yes	No	No	No
9001 S Crenshaw Blvd, Inglewood, CA, 90305, USA	1941 - 1973	11/15/1970	No	Yes	No	No	No
11300 Greenstone Ave, Santa Fe Springs, CA, 90670, USA	1941 - 1973	1/1/1971	No	Yes	No	No	Yes
2491 Foothill Rd, Santa Barbara, CA, 93105, USA	1941 - 1973	1/1/1971	No	Yes	No	No	No
6406 S Main St, Los Angeles, CA, 90003, USA	1941 - 1973	1/1/1971	No	Yes	No	No	Yes
15522 Lake Street, Middletown, CA 95461	1941 - 1973	1/1/1971	Yes	Yes	No	No	No
4285 Eastgate Mall, La Jolla, CA, 92037, USA	1941 - 1973	5/29/1971	No	Yes	No	No	Yes
4864 S. Durfee Ave. Pico Rivera, CA 90660	1941 - 1973	10/17/1971	No	Yes	No	No	No
40404 Rd. 80, Dinuba, CA 93618	1974 -1993	1/1/1972	No	Yes	No	No	Yes
16500 Mulholland Dr, Los Angeles, CA, 90049, USA	1941 - 1973	1/1/1972	No	Yes	No	No	Yes
830 S Reino Rd, Thousand Oaks, CA, 91320, USA	1941 - 1973	1/1/1972	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
10001 Bald Hills Rd, Orick, CA, 95555, USA	1941 - 1973	1/1/1972	No	Yes	No	No	No
2959 Bear Valley Rd, Williams, CA, 95987, USA	1941 - 1973	1/1/1972	No	Yes	No	No	No
7288 Humboldt Rd, Forest Ranch, CA, 95942, USA	1974 -1993	1/1/1972	No	Yes	Yes	No	No
18249 4th Ave, Jamestown, CA, 95327, USA	1941 - 1973	9/9/1972	No	Yes	No	No	Yes
12587 Dexter Park Rd, Sylmar, CA, 91342, USA	1941 - 1973	10/9/1972	No	Yes	No	No	No
16547 Highway 175, Cobb, CA, 95426, USA	1941 - 1973	10/11/1972	No	No	No	No	No
6126 Coventry Ln, Cambria, CA, 93428, USA	1941 - 1973	10/17/1972	No	Yes	No	No	No
1533 Sierra Hwy, Acton, CA, 93510, USA	1941 - 1973	10/29/1972	No	Yes	No	No	No
3375 Fruitland Avenue, Vernon, California 90058	1941 - 1973	11/13/1972	No	Yes	No	No	No
141 W Regent St, Inglewood, CA, 90301, USA	1941 - 1973	11/15/1972	No	Yes	No	No	No
547 Mesa Rd., Santa Barbara, CA 93106	1941 - 1973	1/1/1973	No	Yes	Yes	No	No
1801 De Anza Blvd, San Mateo, CA, 94402, USA	1941 - 1973	1/1/1973	No	Yes	No	No	Yes
3535 W 182nd St, Torrance, CA, 90504, USA	1941 - 1973	1/1/1973	No	Yes	No	No	Yes
8948 Highway 175, Kelseyville, CA, 95451, USA	1941 - 1973	1/1/1973	No	Yes	No	No	No
1401 West 108th Street, Los Angeles, California 90047	1941 - 1973	1/1/1973	No	Yes	No	No	No
1767 W Hammer Ln, Stockton, CA, 95209, USA	1941 - 1973	5/13/1973	No	Yes	No	No	No
10 Wembley Dr, Daly City, CA, 94015, USA	1941 - 1973	5/21/1973	No	Yes	No	No	No
14164 Skyway, Magalia, CA, 95954, USA	1941 - 1973	10/4/1973	No	Yes	No	No	No
2290 Palermo Rd, Palermo, CA, 95968, USA	1941 - 1973	10/7/1973	No	Yes	No		
26829 Seco Canyon Rd, Santa Clarita, CA, 91350, USA	1941 - 1973	10/17/1973	No	Yes	No	No	No
8812 W E-8, Lancaster, CA 93536,	1941 - 1973	10/22/1973	No	Yes	No	No	No
4433 Admiralty Way, Marina Del Rey, CA, 90292, USA	1941 - 1973	10/24/1973	No	Yes	No	No	Yes
755 E Victoria St, Carson, CA, 90746, USA	1941 - 1973	10/30/1973	No	Yes	No	No	No
1124 W. Puente St. San Dimas, CA 91773	1941 - 1973	11/25/1973	No	Yes	No	No	No
1644 Oak St, Solvang, CA, 93463, USA	1974 -1993	1/1/1974	No	Yes	No	No	No
CA-198, Lemon Cove, CA, 93244, USA	1974 -1993	1/1/1974	No	Yes	No	No	Yes
325 W Hillcrest Dr, Thousand Oaks, CA, 91360, USA	1974 -1993	1/1/1974	No	Yes	No	No	No
10631 Skyline Dr, Santa Ana, CA, 92705, USA	1974 -1993	1/1/1974	Yes	Yes	No	No	
9 Shops Blvd, Mission Viejo, CA 92691	1974 -1993	1/1/1974	Yes	Yes	No	No	
18300 Old Monterey Rd, Morgan Hill, CA, 95037, USA	1974 -1993	1/1/1974	No	Yes	No	No	Yes
3775 Rio Rd, Carmel, CA, 93923, USA	1974 -1993	1/1/1974	No	Yes	No	No	Yes
33271 Old Woman Springs Rd, Lucerne Valley, CA, 92356, USA	1974 -1993	1/1/1974	No	Yes	No	No	No
9418 Deschutes Rd, Palo Cedro, CA 96073	1974 -1993	9/25/1974	No	Yes	No	No	Yes
490-105 County A-1, Susanville, CA 96130	1974 -1993	10/7/1974	No	Yes	No	Yes	
31770 Ridge Route Rd, Castaic, CA, 91384, USA	1974 -1993	10/10/1974	No	Yes	No	No	No
1525 S. Nogales Ave. Rowland Heights, CA 91748-2256	1974 -1993	10/17/1974	No	Yes	No	No	No
18355 Bowman Rd, Cottonwood, CA, 96022, USA	1974 -1993	10/21/1974	No	Yes	No	No	No
401 N. Second Ave. Covina, CA 91723	1974 -1993	11/25/1974	No	Yes	No	No	No
5101 Sepulveda Blvd, Sherman Oaks, CA, 91403, USA	1974 -1993	1/1/1975	No	Yes	No	No	Yes
6900 Eureka Rd, Granite Bay, CA, 95746, USA	1974 -1993	1/1/1975	No	Yes	No	No	No
Huntington Vista Rd, Lakeshore, CA, 93634, USA	1974 -1993	1/1/1975	No	Yes	No	No	No
24462 San Vicente Rd, Ramona, CA, 92065, USA	1974 -1993	1/1/1975	No	Yes	No	No	No
3535 N St Helena Hwy, Saint Helena, CA, 94574, USA	1974 -1993	1/1/1975	No	Yes	Yes	No	Yes
1345 Wooden Valley Cross Rd, Napa, CA, 94558, USA	1974 -1993	1/1/1975	No	Yes	No	No	No
326 N Virgil Ave, Los Angeles, CA, 90004, USA	1974 -1993	4/23/1975	No	Yes	No	No	Yes
1100 Linda Mar Blvd, Pacifica, CA, 94044, USA	1974 -1993	5/21/1975	No	Yes	No	No	No
1241 Irvine Blvd, Tustin, CA, 92780, USA	1974 -1993	6/25/1975	Yes	Yes	No	No	
31951 McCoy Rd, Soledad, CA, 93960, USA	1974 -1993	9/25/1975	No	Yes	No	No	No
47 E Gridley Rd, Gridley, CA, 95948, USA	1974 -1993	10/12/1975	No	Yes	No	No	No
1050 W Rancho Vista Blvd, Palmdale, CA, 93551, USA	1974 -1993	10/29/1975	No	Yes	No	No	No
45122 Manter Meadow Dr, California Hot Springs, CA, 93207, USA	1941 - 1973	1/1/1976	No	Yes	No	No	No
7930 Sherwood Blvd, Los Molinos, CA, 96055, USA	1974 -1993	1/1/1976	No	Yes	No	No	No
18355 Bowman Rd, Cottonwood, CA, 96022, USA	1974 -1993	1/1/1976	No	Yes	No	No	No
4040 Carson Rd, Camino, CA, 95709, USA	1974 -1993	1/1/1976	No	Yes	No	Yes	
4949 La Cuenta Dr, San Diego, CA, 92124, USA	1974 -1993	1/1/1976	No	Yes	No	No	Yes
717 N Ventura Ave, Ventura, CA, 93001, USA	1974 -1993	1/1/1976	No	Yes	No	No	Yes
4555 E Riverdale Ave, Anaheim, CA, 92807, USA	1974 -1993	1/1/1976	No	Yes	No	No	No
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1974 -1993	1/1/1976	No	Yes	Yes	No	Yes
809 Nautilus St, San Diego, CA, 92037, USA	1974 -1993	5/28/1976	No	No	No	No	Yes
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1974 -1993	10/2/1976	No	Yes	No	No	No
17501 US-101, Willits, CA 95490	1974 -1993	10/12/1976	No	Yes	Yes	No	No
32550 Pacific Coast Hwy, Malibu, CA, 90265, USA	1974 -1993	10/24/1976	No	Yes	No	No	Yes
4429 Pleasant Valley Rd, Placerville, CA, 95667, USA	1974 -1993	1/1/1977	No	Yes	Yes	No	Yes
725 W Kalmia St, San Diego, CA, 92101, USA	1974 -1993	1/1/1977	Yes	No	No	No	Yes
4225 E Main St, Ventura, CA, 93003, USA	1974 -1993	1/1/1977	No	Yes	No	No	Yes
422 Bassett St, King City, CA 93930	1974 -1993	1/1/1977	No	Yes	No	No	Yes
24462 San Vicente Rd, Ramona, CA, 92065, USA	1974 -1993	1/1/1977	No	Yes	No	No	Yes
625 Kleiber Hall Dr, Davis, CA, 95616, USA	1974 -1993	1/1/1977	No	Yes	No	No	Yes
151 Duesenberg Dr, Thousand Oaks, CA, 91362, USA	1974 -1993	1/1/1977	No	Yes	No	No	No
23831 Stonehill Dr, Dana Point, CA, 92629, USA	1974 -1993	1/1/1977	Yes	Yes	No	No	
802 N Main St, Fort Bragg, CA, 95437, USA	1974 -1993	1/1/1977	No	Yes	No	No	No
930 S Eastern Ave, Los Angeles, CA, 90022, USA	1974 -1993	1/1/1977	No	Yes	No	No	Yes
960 Annapolis Rd, The Sea Ranch, CA, 95497, USA	1974 -1993	1/1/1977	No	Yes	No	No	Yes
19500 Hillsdale Dr, Sonora, CA, 95370, USA	1974 -1993	9/24/1977	No	Yes	No	No	Yes
22133 River View Dr, Cottonwood, CA, 96022, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
4550 East Ave, Livermore, CA, 94550, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
8801 Rock Creek Rd, Placerville, CA, 95667, USA	1974 -1993	1/1/1978	No	Yes	No	No	Yes
6811 De Soto Ave, Canoga Park, CA, 91303, USA	1974 -1993	1/1/1978	No	Yes	No	No	Yes
51345 Eshom Valley Dr, Badger, CA, 93603, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
693 Twining Ave, San Diego, CA, 92154, USA	1974 -1993	1/1/1978	No	No	No	No	Yes
790 Pacific Ave, Simi Valley, CA, 93065, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
4551 Oro Dam Blvd E, Oroville, CA, 95966, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
1108 N. Eastern Ave. Los Angeles, CA 90063	1974 -1993	1/1/1978	No	Yes	No	No	Yes
492 Carpenteria Rd, Aromas, CA, 95004, USA	1974 -1993	1/1/1978	No	Yes	No	No	No
31011 Gonzaga Rd, Gustine, CA, 95322, USA	1974 -1993	1/1/1978	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
40779 Road 128, Cutler, CA, 93615, USA	1974 -1993	4/20/1978	No	No	No	No	No
450 E Temple St, Los Angeles, CA, 90012, USA	1974 -1993	4/23/1978	No	Yes	No	No	Yes
32664 Yucaipa Blvd, Yucaipa, CA, 92399, USA	1974 -1993	10/3/1978	No	Yes	No	No	No
5757 S Fairfax Ave, Los Angeles, CA, 90056, USA	1974 -1993	10/24/1978	No	Yes	No	No	Yes
1815 E 120th St, Los Angeles, CA, 90059, USA	1974 -1993	10/30/1978	No	Yes	No	No	No
2927 Whittier Blvd, Los Angeles, CA, 90023, USA	1974 -1993	1/1/1979	No	Yes	No	No	Yes
4370 S Hoover St, Los Angeles, CA, 90037, USA	1974 -1993	1/1/1979	No	Yes	No	No	Yes
1641 Gray Ave, Yuba City, CA, 95991, USA	1974 -1993	1/1/1979	No	Yes	No	No	No
4302 State Highway 49, Pilot Hill, CA, 95664, USA	1974 -1993	1/1/1979	No	No	No	No	Yes
750 Grand Ave, San Diego, CA, 92109, USA	1974 -1993	1/1/1979	No	Yes	No	No	Yes
1201 E Ojai Ave, Ojai, CA 93023	1974 -1993	1/1/1979	No	Yes	No	No	No
298 Swanton Rd, Davenport, CA, 95017, USA	1941 - 1973	1/1/1979	No	Yes	No	No	Yes
3100 Acreage Ln, Sebastopol, CA, 95472, USA	1941 - 1973	1/1/1979	No	Yes	No	No	No
16310 CA-67, Ramona, CA 92065	1974 -1993	1/1/1979	No	Yes	No	No	Yes
2903 W March Ln, Stockton, CA, 95219, USA	1974 -1993	5/13/1979	No	Yes	No	No	No
4010 E Main St, Stockton, CA, 95215, USA	1974 -1993	5/13/1979	No	Yes	No	No	No
7870 Ardath Ln, San Diego, CA, 92037, USA	1974 -1993	5/28/1979	No	Yes	No	No	Yes
4602 62nd St, San Diego, CA, 92115, USA	1974 -1993	5/28/1979	No	No	No	No	Yes
1979 Fairview Rd, Hollister, CA, 95023, USA	1974 -1993	9/24/1979	No	Yes	No	No	No
11416 Bryant St, Yucaipa, CA, 92399, USA	1974 -1993	10/4/1979	No	Yes	No	No	Yes
120 Eureka Canyon Rd, Watsonville, CA, 95076, USA	1974 -1993	10/6/1979	No	Yes	No	No	No
8710 Sierra Hwy, Santa Clarita, CA, 91390, USA	1974 -1993	10/16/1979	No	Yes	No	No	No
3325 W. Temple Ave. Pomona, CA 91768	1974 -1993	11/25/1979	No	Yes	No	No	No
14334 E. Los Angeles St. Baldwin Park, CA 91706	1974 -1993	11/25/1979	No	Yes	No	No	No
335 Union Ave, Santa Maria, CA, 93455, USA	1994 or later	1/1/1980	No	Yes	No	No	No
1600 Tiffany Park Ct, Santa Maria, CA, 93455, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
702 e 8th street, Alturas, CA 96101	1941 - 1973	1/1/1980	No	No	No	No	No
39431 De Luz Rd, Fallbrook, CA, 92028, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
15123 CR 71 Cal Pines, California	1974 -1993	1/1/1980	No	No	No	No	
3911 Cherokee Rd, Oroville, CA, 95965, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
2335 Ridge Rider Rd, Bradley, CA, 93426, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
22908 Avenue 196, Strathmore, CA, 93267, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
9861 Reseda Blvd, Northridge, CA, 91324, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
1331 W 253rd St, Harbor City, CA, 90710, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
2514 La Brucherie Rd, Imperial, CA, 92251, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
1211 E Swain Rd, Stockton, CA, 95210, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
19287 Hidden Valley Rd, Hidden Valley Lake, CA, 95467, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
140 Traffic Way, Arroyo Grande, CA, 93420, USA	1974 -1993	1/1/1980	Yes	Yes	No	No	Yes
4706 E Drummond Ave, Fresno, CA, 93725, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
5122 Firehouse Rd, Lotus, CA, 95651, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
8441 New Salem St, San Diego, CA, 92126, USA	1974 -1993	1/1/1980	Yes	Yes	No	No	Yes
17701 San Pasqual Valley Rd, Escondido, CA, 92025, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
1800 Mable Ave, Modesto, CA, 95355, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
18464 Striker Ct, Sonora, CA, 95370, USA	1994 or later	1/1/1980	No	Yes	Yes	No	No
1855 New Hogan Pkwy, Valley Springs, CA, 95252, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
Hermit Springs	1994 or later	1/1/1980	No	No	No	No	No
1968 S Lovers Lane, Visalia, CA, 93292, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
16971 Highway 76, Pauma Valley, CA, 92061, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
25858 Highway 78, Ramona, CA, 92065, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
2210 W College Ave, Santa Rosa, CA, 95401, USA	1941 - 1973	1/1/1980	No	Yes	Yes	No	No
37966 CA-299 E, Burney, CA 96013	1974 -1993	1/1/1980	No	Yes	No	No	Yes
31990 CA-44, Shingletown, CA 96088	1974 -1993	1/1/1980	No	Yes	No	No	Yes
25830 State Highway 299 E, Bella Vista, CA 96008.	1974 -1993	1/1/1980	No	Yes	No	No	Yes
5841 Highway 78, Borrego Springs, CA, 92004, USA	1994 or later	1/1/1980	No	Yes	No	No	No
14467 Central Ave, Chino, CA, 91710, USA	1941 - 1973	1/1/1980	No	No	No	No	No
1335 Fortress St, Chico, CA, 95973, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
900 Bello St, Pismo Beach, CA, 93449, USA	1941 or Prior	1/1/1980	No	Yes	No	No	No
19287 Hartmann Rd, Hidden Valley Lake, CA, 95467, USA	1974 -1993	1/1/1980	No	No	No	No	No
8350 Cook Riolo Rd, Roseville, CA, 95747, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
20255 McKean Rd, San Jose, CA, 95120, USA	1974 -1993	1/1/1980	No	Yes	Yes	No	Yes
17501 US-101 N, Willits, CA, 95490, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
17501 United States Highway 101 N, Willits, CA, 95490, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
988 Colusa St, Corning, CA, 96021, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
19597 CA-88, Pine Grove, CA, 95665, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
19500 Hillsdale Dr, Sonora, CA, 95370, USA	1974 -1993	1/1/1980	No	Yes	No	No	Yes
2300 San Felipe Rd, Hollister, CA, 95023, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
21860 Tussing Ranch Rd, Apple Valley, CA, 92308, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
3200 Wright Rd, Camarillo, CA, 93010, USA	1994 or later	1/1/1980	No	Yes	No	Yes	
15670 Monterey Rd, Morgan Hill, CA, 95037, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
880 Manzanita Dr, Los Osos, CA, 93402, USA	1974 -1993	1/1/1980	No	No	No	No	No
2840 Mount Danaher Rd, Camino, CA, 95709, USA	1941 - 1973	1/1/1980	No	Yes	No	No	No
34555 Highway 41, Coarsegold, CA, 93614, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
606 W Bonita Ave, Claremont, CA, 91711, USA	1974 -1993	1/1/1980	No	Yes	No	No	No
185 N Gale Hill Ave, Lindsay, CA, 93247, USA	1941 - 1973	1/1/1980	No	Yes	No	No	Yes
28104 CA-18, Skyforest, CA, 92385, USA	1974 -1993	10/5/1980	No	Yes	No	No	No
22310 Bend Ferry Rd, Red Bluff, CA, 96080, USA	1974 -1993	1/1/1981	No	No	No	No	No
4575 Huntington Dr S, Los Angeles, CA, 90032, USA	1974 -1993	1/1/1981	No	Yes	No	No	Yes
11877 Oak Glen Rd, Yucaipa, CA, 92399, USA	1974 -1993	1/1/1981	No	No	No	No	Yes
18249 4th Ave, Jamestown, CA 95327	1974 -1993	1/1/1981	No	Yes	No	No	No
1505 Main St, Susanville, CA, 96130	1974 -1993	2/1/1981	No	Yes	No	No	No
13393 Salmon River Rd, San Diego, CA, 92129, USA	1974 -1993	5/29/1981	No	Yes	No	No	Yes
26974 Baseline St, Highland, CA, 92346, USA	1974 -1993	10/2/1981	No	Yes	No	No	No
18 Village Loop Rd. Pomona, CA 91766	1974 -1993	11/25/1981	No	Yes	No	No	No
5353 Santa Rosa Rd, Camarillo, CA, 93012, USA	1974 -1993	1/1/1982	No	Yes	No	No	No
3356 Somis Rd, Somis, CA, 93066, USA	1974 -1993	1/1/1982	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
2535 Zanella Way, Chico, CA, 95928, USA	1974 -1993	1/1/1982	No	No	No	No	No
2100 E Dunne Ave, Morgan Hill, CA, 95037, USA	1974 -1993	1/1/1982	No	Yes	No	No	No
8355 Mountain View Rd, Kneeland, CA, 95549, USA	1974 -1993	1/1/1982	No	Yes	No	No	No
2110 Via Casa Alta, San Diego, CA, 92037, USA	1974 -1993	5/29/1982	No	No	No	No	Yes
2055 Lincoln St, Oroville, CA, 95966, USA	1974 -1993	6/11/1982	Yes	Yes	Yes	No	No
15815 Morro Rd, Atascadero, CA, 93422, USA	1974 -1993	1/1/1983	No	No	No	No	No
24919 Marion Ridge Dr, Idyllwild, CA, 92549, USA	1974 -1993	1/1/1983	Yes	Yes	No	No	No
33015 Bautista Canyon Rd, Hemet, CA, 92544, USA	1974 -1993	1/1/1983	No	No	No	No	No
7200 Saint Florian Ct, Cool, CA, 95614, USA	1974 -1993	1/1/1984	No	Yes	No	No	Yes
16650 Cachagua Rd, Carmel Valley, CA, 93924, USA	1974 -1993	1/1/1984	No	Yes	No	No	No
8709 Circle R Dr, Escondido, CA, 92026, USA	1974 -1993	1/1/1984	No	Yes	No	No	No
1112 Wise Rd, Lincoln, CA, 95648, USA	1974 -1993	1/1/1984	No	Yes	No	No	No
10655 Round Valley Rd, Paskenta, CA 96074	1974 -1993	1/1/1984	No	No	No	No	No
24190 Kewin Mill Rd, Sonora, CA, 95370, USA	1974 -1993	9/8/1984	No	Yes	No	No	Yes
20011 La Puente Rd. Walnut, CA 91789-1719	1974 -1993	10/17/1984	No	Yes	No	No	No
14815 Olympic Dr, Clearlake, CA, 95422, USA	1974 -1993	1/1/1985	No	Yes	No	No	Yes
330 Ferry St, San Pedro, CA, 90731, USA	1974 -1993	1/1/1985	No	Yes	No	No	Yes
855 Deerhill Rd, Oak Park, CA, 91377, USA	1974 -1993	1/1/1985	No	Yes	No	No	No
3101 Forest Lake Rd, Pebble Beach, CA, 93953, USA	1974 -1993	1/1/1985	No	Yes	Yes	No	No
19030 Pioneer Blvd, Cerritos, CA, 90703, USA	1994 or later	1/1/1985	No	Yes	No	No	No
463-390 Main St, Janesville, CA, 96114, USA	1994 or later	4/22/1985	No	Yes	No	No	No
3505 Auburn Folsom Rd, Loomis, CA, 95650, USA	1974 -1993	5/16/1985	No	Yes	No	No	Yes
6103 Airport Rd, Redding, CA, 96002, USA	1974 -1993	10/2/1985	No	Yes	No	No	Yes
12845 Oroville Quincy Hwy, Oroville, CA 95966	1974 -1993	10/7/1985	No	Yes	No	No	No
33957 Longview Rd, Pearblossom, CA, 93553, USA	1974 -1993	10/29/1985	No	Yes	No	No	No
1860 E Del Amo Blvd, Carson, CA, 90746, USA	1974 -1993	10/30/1985	No	Yes	No	No	No
4560 Rowles Rd, Vina, CA, 96092, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
6300 Stoneridge Mall Rd, Pleasanton, CA, 94588, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
21401 Del Amo Cir W, Torrance, CA, 90503, USA	1974 -1993	1/1/1986	No	Yes	No	No	Yes
3434 Ocean View Blvd, San Diego, CA, 92113, USA	1974 -1993	1/1/1986	No	Yes	No	No	Yes
9700 E American Ave, Del Rey, CA, 93616, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
4925 Nelson Ave, Clovis, CA, 93619, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
8270 E Monte Vista Rd, Anaheim, CA, 92808, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
36421 S Lassen Ave, Huron, CA, 93234, USA	1974 -1993	1/1/1986	No	Yes	No	No	Yes
24125 W Dorris Ave, Coalinga, CA, 93210, USA	1974 -1993	1/1/1986	No	Yes	No	No	No
308 Pine St, Mount Shasta, CA, 96067, USA	1974 -1993	1/1/1986	No	Yes	No	No	Yes

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
4560 Rowles Rd, Vina, CA, 96092, USA	1974-1993	1/1/1986	No	Yes	No	No	No
6300 Stoneridge Mall Rd, Pleasanton, CA, 94588, USA	1974-1993	1/1/1986	No	Yes	No	No	No
21401 Del Amo Cir W, Torrance, CA, 90503, USA	1974-1993	1/1/1986	No	Yes	No	No	Yes
3434 Ocean View Blvd, San Diego, CA, 92113, USA	1974-1993	1/1/1986	No	Yes	No	No	Yes
9700 E American Ave, Del Rey, CA, 93616, USA	1974-1993	1/1/1986	No	Yes	No	No	No
4925 Nelson Ave, Clovis, CA, 93619, USA	1974-1993	1/1/1986	No	Yes	No	No	No
8270 E Monte Vista Rd, Anaheim, CA, 92808, USA	1974-1993	1/1/1986	No	Yes	No	No	No
36421 S Lassen Ave, Huron, CA, 93234, USA	1974-1993	1/1/1986	No	Yes	No	No	Yes
24125W W Dorris Ave, Coalinga, CA, 93210, USA	1974-1993	1/1/1986	No	Yes	No	No	No
308 Pine St, Mount Shasta, CA, 96067, USA	1974-1993	1/1/1986	No	Yes	No	No	Yes
2661 Beach Rd, Watsonville, CA, 95076, USA	1974-1993	10/6/1986	No	Yes	No	No	No
20480 Pathfinder Rd. Walnut, CA 91789-4620	1974-1993	10/17/1986	No	Yes	No	No	No
10 W Pennsylvania Ave, Redlands, CA, 92374, USA	1974-1993	11/14/1986	No	Yes	No	No	Yes
1410 Cypress Ave, Los Angeles, CA, 90065, USA	1974-1993	1/1/1987	No	Yes	No	No	Yes
1601 S Grand Ave, San Pedro, CA, 90731, USA	1974-1993	1/1/1987	No	Yes	No	No	Yes
5821 W 3rd St, Los Angeles, CA, 90036, USA	1974-1993	1/1/1987	No	Yes	No	No	Yes
5023 W Washington Blvd, Los Angeles, CA, 90016, USA	1974-1993	1/1/1987	No	Yes	No	No	Yes
4650 E Roseville Pkwy, Granite Bay, CA, 95746, USA	1974-1993	1/1/1987	No	No	No	No	No
10797 Darling Rd, Ventura, CA, 93004, USA	1974-1993	1/1/1987	No	Yes	No	No	Yes
2141 W Crescent Ave, Anaheim, CA, 92801, USA	1974-1993	1/1/1987	No	Yes	No	No	No
536 W Main St, Santa Paula, CA, 93060, USA	1974-1993	1/1/1987	No	Yes	No	No	No
18930 State Highway 120, Groveland, CA, 95321, USA	1974-1993	7/1/1987	No	Yes	No	No	No
4518 West Lennox Boulevard, Inglewood, California 90304	1974-1993	11/15/1987	No	Yes	No	No	No
29960 Plum Creek Rd, Paynes Creek, CA, 96075, USA	1974-1993	1/1/1988	No	Yes	No	No	No
4957 Melrose Ave, Los Angeles, CA, 90029, USA	1974-1993	1/1/1988	No	Yes	No	No	Yes
7800 S Vermont Ave, Los Angeles, CA, 90044, USA	1974-1993	1/1/1988	No	Yes	No	No	Yes
1166 S Greenwood Ave, Montebello, CA, 90640, USA	1974-1993	1/1/1988	No	Yes	No	No	Yes
12119 World Trade Dr, San Diego, CA, 92128, USA	1974-1993	1/1/1988	No	Yes	No	No	Yes
1910 Church St, Simi Valley, CA, 93065, USA	1974-1993	1/1/1988	No	Yes	No	No	No
3337 County Road 307, Elk Creek, Ca 95939	1974-1993	1/1/1988	No	Yes	No	No	Yes
6031 Rickenbacker RD. Commerce, CA 90040	1974-1993	1/1/1988	No	Yes	No	No	Yes
2644 N. San Gabriel Blvd Rosemead, CA 91770	1974-1993	1/1/1988	No	Yes	No	No	Yes
11817 Anaconda Ave, Victorville, CA, 92392, USA	1974-1993	1/1/1988	No	Yes	No	No	No
9858 Cohasset Rd, Chico, CA, 95973, USA	1974-1993	1/1/1988	No	Yes	No	No	No
23260 Elmore Rd, Groveland, CA, 95321, USA	1974-1993	9/9/1988	No	Yes	No	No	Yes
30377 Oak Run to Fern Rd, Oak Run, CA 96069	1974-1993	10/2/1988	No	Yes	No	No	Yes
46833 Ralphs Ranch Rd, Lebec, CA, 93243, USA	1974-1993	10/10/1988	No	Yes	No	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
23260 Elmore Rd, Groveland, CA, 95321, USA	1974 -1993	9/9/1988	No	Yes	No	No	Yes
30377 Oak Run to Fern Rd, Oak Run, CA 96069	1974 -1993	10/2/1988	No	Yes	No	No	Yes
46833 Ralphs Ranch Rd, Lebec, CA, 93243, USA	1974 -1993	10/10/1988	No	Yes	No	No	No
17200 Calle Mariposa Reina, Goleta, CA, 93117, USA	1974 -1993	1/1/1989	No	Yes	No	No	No
1439 N Gardner St, Los Angeles, CA, 90046, USA	1974 -1993	1/1/1989	No	Yes	No	No	Yes
4455 York Blvd, Los Angeles, CA, 90041, USA	1974 -1993	1/1/1989	No	Yes	No	No	Yes
2759 Rowena Ave, Los Angeles, CA, 90039, USA	1974 -1993	1/1/1989	No	Yes	No	No	Yes
1909 W Slauson Ave, Los Angeles, CA, 90047, USA	1974 -1993	1/1/1989	No	Yes	No	No	Yes
7419 Reseda Blvd, Reseda, CA, 91335, USA	1974 -1993	1/1/1989	No	Yes	No	No	Yes
6051 Gold Hill Rd, Placerville, CA, 95667, USA	1974 -1993	1/1/1989	No	No	No	No	Yes
5674 West Pacific Coast Highway, Ventura, CA 93001	1974 -1993	1/1/1989	No	Yes	No	No	No
4185 Cedar Springs St, Moorpark, CA, 93021, USA	1974 -1993	1/1/1989	No	Yes	No	No	No
1050 Country Club Dr, Simi Valley, CA, 93065, USA	1974 -1993	1/1/1989	No	Yes	No	No	No
17304 Highway 94, Dulzura, CA, 91917, USA	1994 or later	1/1/1989	No	Yes	No	No	No
4676 Felton St, San Diego, CA, 92116, USA	1974 -1993	5/29/1989	No	Yes	No	No	Yes
346 Armitos Pl, Diamond Bar, CA, 91765, USA	1974 -1993	11/25/1989	No	Yes	No	No	No
906 Airport Rd, Santa Ynez, CA, 93460, USA	1974 -1993	1/1/1990	No	Yes	Yes	No	No
20230 Hwy 36W, Red Bluff, CA, 96080, USA.	1974 -1993	1/1/1990	No	Yes	No	No	No
17195 Rancho Tehama Rd, Corning, CA, 96021, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
2961 Alhambra Dr, Cameron Park, CA, 95682, USA	1974 -1993	1/1/1990	No	Yes	No	No	Yes
41412 S Fork Dr, Three Rivers, CA, 93271, USA	1941 - 1973	1/1/1990	No	No	No	No	No
4914 Carroll Canyon Rd, San Diego, CA, 92121, USA	1974 -1993	1/1/1990	No	Yes	No	No	Yes
21610 Crestline Rd, Palomar Mountain, CA, 92060, USA	1974 -1993	1/1/1990	No	Yes	No	No	Yes
125 Bremer St, Weaverville, CA, 96093, USA	1974 -1993	1/1/1990	No	Yes	No	No	Yes
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No		
2800 Wright Rd, Camarillo, CA, 93010	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA, 93010	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA 93010	1974 -1993	1/1/1990	No	Yes	No	No	No
7000 Garfield Ave, Bell Gardens, CA, 90201, USA	1974 -1993	1/1/1990	No	Yes	No	No	Yes
2800 Wright Rd, Camarillo, CA, 93010	1974 -1993	1/1/1990	No	No	No	No	No
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
2800 Wright Rd, Camarillo, CA, 93010, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
8800 N Old Stage Rd, Weed, CA, 96094, USA	1974 -1993	1/1/1990	No	Yes	No	No	No
595 San Ysidro Rd, Santa Barbara, CA, 93108, USA	1974 -1993	5/23/1990	No	Yes	No	No	Yes
24592 Viejas Grade Rd, Descanso, CA 91916	1974 -1993	5/30/1990	No	Yes	No	No	Yes
13795 CA-120, Jamestown, CA, 95327, USA	1974 -1993	9/8/1990	No	Yes	No	No	Yes
555 N Villa Ave, Clovis, CA, 93611, USA	1974 -1993	9/24/1990	No	Yes	No	No	No
29507 Baseline St, Highland, CA, 92346, USA	1974 -1993	10/3/1990	No	Yes	No	No	Yes
83 Miraleste Pl, Rancho Palos Verdes, CA, 90275, USA	1974 -1993	10/30/1990	No	Yes	No	No	No
2595 Mecartney Rd, Alameda, CA, 94502, USA	1974 -1993	1/1/1991	No	Yes	No		
4029 Wilshire Blvd, Los Angeles, CA, 90010, USA	1974 -1993	1/1/1991	No	Yes	No	No	Yes
31461 Street of the Golden Lantern, Laguna Niguel, CA, 92677, USA	1974 -1993	1/1/1991	No	Yes	No	No	
1255 Jacumba St, Jacumba, CA, 91934, USA	1974 -1993	10/1/1991	No	Yes	No	No	
2391 Willow Rd, Arroyo Grande, CA, 93420, USA	1974 -1993	10/8/1991	No	Yes	No	No	Yes
1509 Squaw Valley Rd, McCloud, CA, 96057, USA	1974 -1993	10/14/1991	No	Yes	No	No	No
44851 30th St E, Lancaster, CA, 93535, USA	1974 -1993	10/22/1991	No	Yes	No	No	No
21095 CA-175, Middletown, CA, 95461, USA	1974 -1993	1/1/1992	No	No	No	No	No
1327 Cole Ave, Los Angeles, CA, 90028, USA	1994 or later	1/1/1992	No	Yes	No	No	Yes
11641 Corbin Ave, Porter Ranch, CA, 91326, USA	1994 or later	1/1/1992	No	Yes	No	No	Yes
2945 Miner St, San Pedro, CA, 90731, USA	1974 -1993	1/1/1992	No	Yes	No	No	Yes
444 S Harbor Blvd, San Pedro, CA, 90731, USA	1974 -1993	1/1/1992	No	Yes	No	No	Yes
6300 E Nohl Ranch Rd, Anaheim, CA, 92807, USA	1974 -1993	1/1/1992	No	Yes	No	No	No
3410 Dye Rd, Ramona, CA, 92065, USA	1974 -1993	1/1/1992	No	Yes	No	No	Yes
500 N Newcomb St, Porterville, CA, 93257, USA	1974 -1993	1/1/1992	No	Yes	No	No	No
9305 Wise Rd, Auburn, CA, 95603, USA	1974 -1993	1/1/1992	No	Yes	Yes	No	No
14467 Central Ave, Chino, CA, 91710, USA	1974 -1993	1/1/1992	No	Yes	No	No	No
3445 Bayshore Blvd, Brisbane, CA, 94005, USA	1974 -1993	5/21/1992	No	Yes	No	No	No
4011 32nd St, San Diego, CA, 92104, USA	1974 -1993	5/28/1992	No	No	No	No	Yes
300 Edmonds Rd, Redwood City, CA, 94062	1974 -1993	6/13/1992	No	Yes	No	No	No
16064 Homestake Rd, Redding, CA 96001	1974 -1993	10/2/1992	No	Yes	No	No	Yes
21095 CA-175, Middletown, CA, 95461, USA	1974 -1993	10/11/1992	No	No	No	No	No
44558 40th St W, Lancaster, CA, 93536, USA	1974 -1993	10/24/1992	No	Yes	No	No	No
3701 N. Mills Ave. Claremont, CA 91711	1974 -1993	11/25/1992	No	Yes	No	No	No
164 S Walnut Ave, San Dimas, CA, 91773, USA	1974 -1993	11/25/1992	No	Yes	No	No	No
6115 Grange Rd, Corning, CA, 96021, USA	1974 -1993	1/1/1993	No	No	No	No	No
759 Lincoln Rd, Yuba City, CA, 95991, USA	1974 -1993	1/1/1993	No	Yes	No	No	No
2855 Butte House Rd, Yuba City, CA, 95993, USA	1974 -1993	1/1/1993	No	Yes	No	No	No
270 Alpine Meadows Rd, Alpine Meadows, CA, 96146, USA	1974 -1993	1/1/1993	No	Yes	No	No	Yes
23600 Pacific Island Dr, Laguna Niguel, CA, 92677, USA	1974 -1993	1/1/1993	No	Yes	No	No	
7276 Empire Grade, Santa Cruz, CA 95060	1974 -1993	1/1/1993	No	Yes	No	No	No
760 Mattie Rd, Pismo Beach, CA, 93449, USA	1974 -1993	1/1/1993	No	No	No	No	No
2383 Honey Springs Rd, Jamul, CA, 91935, USA	1974 -1993	1/1/1993	No	Yes	No	No	No
16115 Jamison Creek Rd, Boulder Creek, CA, 95006, USA	1974 -1993	1/1/1993	No	Yes	No	No	No
3318 Topeka St, Riverbank, CA, 95367, USA	1974 -1993	5/6/1993	No	Yes	No	No	Yes
3019 McNabb St, Stockton, CA, 95209, USA	1974 -1993	5/13/1993	No	Yes	No	No	No
13077 Hartfield Ave, San Diego, CA, 92130, USA	1974 -1993	5/29/1993	No	Yes	No	No	Yes
1555 Airport Blvd, Napa, CA, 94558, USA	1974 -1993	10/4/1993	No	Yes	No	No	Yes
29599 CA-89, Burney, CA, 96013, USA	1974 -1993	10/14/1993	No	Yes	No	No	No
4180 17 Mile Dr, Pebble Beach, CA, 93953, USA	1994 or later	1/1/1994	No	Yes	No	No	Yes
1200 Machado Pl, Pleasanton, CA, 94566, USA	1994 or later	1/1/1994	No	Yes	No	No	No
1818 S Fresno Ave, Stockton, CA, 95206, USA	1994 or later	1/1/1994	No	Yes	No	No	No


Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
11490 Pioneer Rd, Tustin, CA, 92782, USA	1994 or later	1/1/1994	No	Yes	No	No	
7288 Humboldt Rd, Forest Ranch, CA, 95942, USA	1994 or later	1/1/1994	No	Yes	No	No	No
3499 Manthey Rd, Stockton, CA, 95206, USA	1994 or later	5/13/1994	No	Yes	No	No	No
101 McCabe Ave, Mendota, CA, 93640, USA	1994 or later	6/2/1994	No	Yes	Yes	No	No
29690 Oak Dr, Campo, CA, 91906, USA	1994 or later	9/28/1994	No	Yes	No	No	No
42110 6th St W, Lancaster, CA, 93534, USA	1994 or later	10/24/1994	No	Yes	No	No	Yes
8010 Compton Ave, Los Angeles, CA, 90001, USA	1994 or later	11/15/1994	No	Yes	No	No	No
5330 Calle Real, Santa Barbara, CA, 93111, USA	1941 - 1973	1/1/1995	No	Yes	No		
1444 S Seaside Ave, San Pedro, CA, 90731, USA	1994 or later	1/1/1995	No	Yes	No	No	Yes
1590 La Media Rd, San Diego, CA, 92154, USA	1994 or later	1/1/1995	No	Yes	No	No	Yes
5841 Highway 78, Borrego Springs, CA 92004	1994 or later	1/1/1995	No	Yes	No	No	Yes
2160 Pickwick Dr, Camarillo, CA, 93010, USA	1994 or later	1/1/1995	No	Yes	No	No	No
Ben Hulse Hwy, Palo Verde, CA, 92266, USA	1994 or later	6/1/1995	No	Yes	No	No	
41640 Dinkey Creek Rd, Shaver Lake, CA, 93664, USA	1994 or later	9/24/1995	No	Yes	No	No	No
1551 Sparrow St, San Luis Obispo, CA, 93405, USA	1994 or later	10/13/1995	No	Yes	No	No	Yes
43225 25th St W, Lancaster, CA, 93536, USA	1994 or later	10/24/1995	No	Yes	No	No	No
1846 E Avenue K4, Lancaster, CA, 93535, USA	1994 or later	10/24/1995	No	Yes	No	No	Yes
4312 W 147th St, Lawndale, CA, 90260, USA	1994 or later	10/30/1995	No	Yes	No	No	No
9580 State Highway 99w, Gerber, CA, 96035, USA	1994 or later	1/1/1996	No	Yes	No	No	No
16211 US Highway 50, Strawberry, CA, 95720, USA	1994 or later	1/1/1996	No	No	No	No	Yes
829 San Vicente Rd, Ramona, CA, 92065, USA	1994 or later	1/1/1996	No	Yes	No	No	Yes
2845 Lumpkin Rd, Oroville, CA, 95966, USA	1994 or later	1/1/1996	No	Yes	No	No	
201 S Shepherd St, Sonora, CA, 95370, USA	1994 or later	1/1/1996	No	Yes	Yes	No	Yes
829 San Vicente Rd, Ramona, CA, 92065, USA	1994 or later	1/1/1996	No	Yes	No	No	No
464 Martin St, Daly City, CA, 94014, USA	1994 or later	5/21/1996	No	Yes	No	No	No
17759 Skyline Truck Trail, Jamul, CA, 91935, USA	1994 or later	9/28/1996	No	Yes	No	No	No
35655 Sage Rd, Hemet, CA, 92544, USA	1994 or later	10/29/1996	Yes	Yes	No		
5750 Scenic Ave, Livermore, CA, 94551, USA	1994 or later	1/1/1997	No	Yes	No	No	No
945 25th St, San Diego, CA, 92102, USA	1994 or later	1/1/1997	No	Yes	No	No	Yes
6812 Elwood Rd, Sanger, CA, 93657, USA	1994 or later	1/1/1997	No	Yes	No	No	No
27595 Tollhouse Rd, Tollhouse, CA, 93667, USA	1994 or later	1/1/1997	No	Yes	No	No	No
2330 Pasadena Ave, Los Angeles, CA, 90031, USA	1994 or later	4/23/1997	No	Yes	No	No	Yes
176 Nelson Ave, Oroville, CA, 95965, USA	1994 or later	10/3/1997	No	Yes	Yes	No	No
4050 Branch Rd, Paso Robles, CA, 93446, USA	1994 or later	10/10/1997	No	Yes	No	No	Yes
988 Colusa St, Corning, CA, 96021, USA	1994 or later	1/1/1998	No	Yes	No	No	No
1717 S Clementine St, Anaheim, CA, 92802, USA	1994 or later	1/1/1998	No	Yes	No	No	No
1191 Main St, Half Moon Bay, CA, 94019, USA	1994 or later	1/1/1998	No	Yes	Yes	Yes	
1820 Monticello Rd, Napa, CA, 94558, USA	1994 or later	1/1/1998	No	Yes	No	No	No
1820 Monticello Rd, Napa, CA, 94558, USA	1994 or later	1/1/1998	No	Yes	No	No	No
3800 N Sierra Way, San Bernardino, CA, 92405, USA	1994 or later	1/1/1998	No	Yes	Yes	No	No
501 W Centre St, Shandon, CA, 93461, USA	1994 or later	1/1/1998	No	Yes	No	No	No
21720 Phoenix Lake Rd, Sonora, CA 95370	1994 or later	9/8/1998	No	Yes	No	No	Yes
8839 State Highway 20, Smartsville, CA, 95977, USA	1994 or later	10/1/1998	No	Yes	No	No	No
30656 Hagen Flat Rd, Big Bend, CA 96011	1994 or later	10/2/1998	No	Yes	No	No	Yes
17056 Gale Ave. City of Industry, CA 91745	1994 or later	10/17/1998	No	Yes	No	No	No
2629 E Avenue S, Palmdale, CA, 93550, USA	1994 or later	10/29/1998	No	Yes	No	No	No
330 Airway Blvd, Livermore, CA, 94551, USA	1994 or later	1/1/1999	No	Yes	No	No	No
701 Rockaway Ave, Grover Beach, CA, 93433, USA	1994 or later	1/1/1999	No	Yes	No	No	Yes
501 Pleasant Valley Rd, Diamond Springs, CA, 95619, USA	1994 or later	1/1/1999	No	Yes	No	No	No
380 Oak Ave, Greenfield, CA, 93927, USA	1994 or later	1/1/1999	No	Yes	No	No	Yes
7260 Great Southern Overland Rte. of, Julian, CA, 92036, USA	1994 or later	1/1/1999	No	Yes	No	No	Yes
7401 Solano Ave, Yountville, CA, 94599, USA	1994 or later	1/1/1999	No	Yes	No	No	No
8900 Gilroy Hot Springs Rd, Gilroy, CA, 95020, USA	1994 or later	1/1/1999	No	Yes	No	No	No
73 Fern Canyon Rd, Carmel-by-the-Sea, CA, 93923, USA	1994 or later	1/1/1999	No	Yes	No	No	Yes
9740 Mountain Ranch Rd, Mountain Ranch, CA, 95246, USA	1994 or later	1/1/1999	No	Yes	No	No	No
33 Apple Blossom Dr, Murphys, VA 95247	1994 or later	1/1/1999	No	Yes	No	No	No
11000 S Highway 101, Hopland, CA, 95449, USA	1994 or later	1/1/1999	No	Yes	No	No	Yes
35227 Highway 79, Warner Springs, CA, 92086, USA	1994 or later	9/30/1999	No	Yes	No	No	No
11518 Platina Rd, Igo, CA 96047	1994 or later	10/2/1999	No	Yes	No	No	Yes
11485 Loma Rica Rd, Marysville, CA, 95901, USA	1994 or later	10/5/1999	No	Yes	No	No	Yes
2510 Ramada Dr, Paso Robles, CA, 93446, USA	1941 or Prior	1/1/2000	No	Yes	No	No	
2510 Ramada Dr, Paso Robles, CA, 93446, USA	1941 or Prior	1/1/2000	No	Yes	No	No	
16502 W Schulte Rd, Tracy, CA, 95377, USA	1994 or later	1/1/2000	No	Yes	No	No	No
15 Kunkle St, Oak View, CA 93022	1994 or later	1/1/2000	No	Yes	No	No	No
25600 Jayne Ave, Coalinga, CA, 93210, USA	1994 or later	1/1/2000	No	Yes	No	No	No
31577 Highway 94, Campo, CA, 91906, USA	1994 or later	1/1/2000	No	Yes	No	No	No
7882 Quartz St, Stirling City, CA, 95978, USA	1994 or later	1/1/2000	No	Yes	No	No	No
10277 Truckee Airport Rd, Truckee, CA, 96161, USA	1994 or later	1/1/2000	No	Yes	No	No	No
300 Edmonds Rd, Redwood City, CA, 94062, USA	1994 or later	1/1/2000	No	Yes	No	No	No
44947 Date Ave, Lancaster, CA, 93534, USA	1994 or later	1/1/2000	No	Yes	No	No	No
1 Pinecrest Ave, Pinecrest, CA, 95364, USA	1994 or later	9/8/2000	No	Yes	No	No	Yes
2427 Armstrong Ave, Clovis, CA, 93611, USA	1994 or later	9/24/2000	No	Yes	No	No	No
41722 Little Lake Rd, Mendocino, CA, 95460, USA	1994 or later	10/16/2000	No	Yes	No	No	No
324 Alderpoint Rd, Garberville, California, 95542	1994 or later	12/6/2000	No	Yes	Yes	No	No
25050 Highland Way, Los Gatos, CA, 95033, USA	1994 or later	1/1/2001	No	Yes	No	No	No
900 Park St, Paso Robles, CA 93446, USA	1994 or later	1/1/2001	No	Yes	Yes	Yes	
11640 Spring Canyon Rd, San Diego, CA, 92131, USA	1994 or later	1/1/2001	No	Yes	No	No	Yes
304 N 2nd St, Port Hueneme, CA, 93041, USA	1994 or later	1/1/2001	No	Yes	No	No	No
189 S Las Posas Rd, Camarillo, CA, 93010, USA	1994 or later	1/1/2001	No	Yes	Yes	No	No
2010 Upper Ranch Rd, Thousand Oaks, CA, 91362, USA	1994 or later	1/1/2001	No	Yes	No	No	No
605 Antelope Blvd, Red Bluff, CA, 96080, USA	1994 or later	1/1/2001	No	No	Yes	No	Yes
5560 Old Stage Rd, Porterville, CA 93257	1994 or later	1/1/2001	No	Yes	No	No	No
121 S 10th St, Montague, CA, 96064, USA	1994 or later	7/1/2001	No	Yes	No	No	Yes
31385 CA-299, Montgomery Creek, CA 96065	1994 or later	10/2/2001	No	Yes	No	No	Yes
1464 Forest Service Rd, Paradise, CA, 95969, USA	1994 or later	10/3/2001	No	Yes	Yes	No	No

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
3403 Taxi Way A, Paso Robles, CA 93446	1994 or later	10/8/2001	No	No	No		
864 N San Vicente Blvd, West Hollywood, CA, 90069, USA	1994 or later	10/23/2001	No	Yes	No	No	Yes
864 N San Vicente Blvd, West Hollywood, CA, 90069, USA	1994 or later	11/4/2001	No	Yes	No	No	Yes
3560 Nevada St, Pleasanton, CA, 94566, USA	1994 or later	1/1/2002	No	Yes	Yes	No	No
951 Rincon Ave, Livermore, CA, 94551, USA	1994 or later	1/1/2002	No	Yes	No	No	No
1500 Marina Ct, San Mateo, CA, 94403, USA	1994 or later	1/1/2002	No	Yes	No	No	Yes
1040 E Hillsdale Blvd, Foster City, CA, 94404, USA	1994 or later	1/1/2002	No	Yes	Yes	No	Yes
10011 Black Mountain Rd, San Diego, CA, 92126, USA	1994 or later	1/1/2002	No	Yes	No	No	Yes
1330 S Euclid St, Anaheim, CA, 92802, USA	1994 or later	1/1/2002	No	Yes	Yes	No	No
1300 Athens Ave, Lincoln, CA 95648	1994 or later	1/1/2002	No	Yes	No	No	No
4795 Foothill Blvd, Oroville, CA, 95966, USA	1994 or later	1/1/2002	No	No	No	No	No
20810 Tomira Meadow Rd, Tuolumne, CA, 95379, USA	1994 or later	1/1/2002	No	Yes	No	No	Yes
4820 Heritage Rd, Paso Robles, CA, 93446, USA	1994 or later	10/14/2002	No	Yes	No	No	No
25870 Hemingway Ave, Stevenson Ranch, CA, 91381, USA	1994 or later	10/18/2002	No	Yes	No	No	No
26320 Citrus St, Valencia, CA, 91355, USA	1994 or later	10/18/2002	No	Yes	No	No	No
10508 CA-49, Coulterville, CA, 95311, USA	1994 or later	11/16/2002	No	Yes	No	No	No
31291 Manton Rd, Manton, CA, 96059, USA	1994 or later	1/1/2003	No	Yes	No	No	No
13050 Soda Lake Rd, Santa Margarita, CA, 93453, USA	1994 or later	1/1/2003	No	Yes	No	No	No
911 Granada St, Belmont, CA, 94002, USA	1994 or later	1/1/2003	No	Yes	Yes	No	Yes
7070 Auburn Folsom Rd, Granite Bay, CA, 95746, USA	1994 or later	1/1/2003	No	No	No	No	Yes
2125 S Newcomb St, Porterville, CA, 93257, USA	1994 or later	1/1/2003	No	No	No	No	No
1300 Athens Ave, Lincoln, CA, 95648, USA	1994 or later	1/1/2003	No	Yes	No	No	Yes
31200 Manton Rd, Manton, CA, 96059, USA	1994 or later	1/1/2003	No	Yes	No	No	No
3200 Country Club Dr, Cameron Park, CA, 95682, USA	1994 or later	1/1/2004	No	Yes	No	No	No
7063 Laurel Canyon Blvd, North Hollywood, CA, 91605, USA	1994 or later	1/1/2004	No	Yes	No	No	Yes
14556 Lazanja Dr, San Diego, CA, 92127, USA	1994 or later	1/1/2004	No	No	No	No	Yes
1255 Jacumba St, Jacumba, CA, 91934, USA	1994 or later	1/1/2004	No	Yes	No	No	Yes
25858A Highway 78, Ramona, CA, 92065, USA	1994 or later	1/1/2004	No	Yes	No	No	Yes
305 Olympic Valley Rd, Olympic Valley, CA, 96146, USA	1994 or later	1/1/2004	No	Yes	No	No	No
295 E High St, Moorpark, CA, 93021, USA	1994 or later	1/1/2004	No	Yes	Yes	No	No
18 Bepler St, Daly City, CA, 94014, USA	1994 or later	5/21/2004	No	Yes	No	No	No
14946 Vesper Rd, Valley Center, CA, 92082, USA	1994 or later	1/1/2005	No	Yes	No		
1050 Wilson Blvd, El Dorado Hills, CA, 95762, USA	1994 or later	1/1/2005	No	Yes	No	No	Yes
1600 Oak Vista Way, Pleasanton, CA, 94566, USA	1994 or later	1/1/2005	No	Yes	No	No	No
4960 Balboa Blvd, Encino, CA, 91316, USA	1994 or later	1/1/2005	No	Yes	No	No	Yes
9224 Sunland Blvd, Sun Valley, CA, 91352, USA	1994 or later	1/1/2005	No	Yes	No	No	Yes
198 W San Ysidro Blvd, San Diego, CA, 92173, USA	1994 or later	1/1/2005	No	Yes	No	No	Yes
3302 Turnout Park Cir, Oxnard, CA, 93036, USA	1994 or later	1/1/2005	No	Yes	No	No	No
40900 Sierra Dr, Three Rivers, CA, 93271, USA	1994 or later	1/1/2005	No	Yes	No	No	No
551 Harbison Canyon Rd, El Cajon, CA, 92019, USA	1994 or later	1/1/2005	No	Yes	No	No	No
562 Casserly Rd, Watsonville, CA, 95076, USA	1994 or later	1/1/2005	No	Yes	No	No	No
14946 Vesper Rd, Valley Center, CA, 92082, USA	1994 or later	1/1/2005	No	Yes	No	No	Yes
29721 highway 36E, Paynes Creek, CA 96080	1994 or later	1/1/2005	No	Yes	No	No	No
9600 Centola Rd, Phelan, CA, 92371, USA	1994 or later	1/1/2005	No	Yes	No	No	No
4964 Imperial Ave, San Diego, CA, 92113, USA	1994 or later	5/28/2005	No	Yes	No	No	Yes
32515 E Kings Canyon Rd, Squaw Valley, CA, 93675, USA	1994 or later	9/24/2005	No	Yes	No	No	No
53488 Rd. 200, O'Neals, CA 93645	1994 or later	11/15/2005	No	Yes	No	No	No
2690 N State St, Ukiah, CA, 95482, USA	1994 or later	1/1/2006	No	Yes	No	No	No
34295 Wildwood Canyon Rd, Yucaipa, CA, 92399, USA	1994 or later	1/1/2006	No	Yes	No	No	Yes
400 15th St, Manhattan Beach, CA, 90266, USA	1994 or later	1/1/2006	No	Yes	Yes	No	No
1801 E Century Blvd, Los Angeles, CA, 90002, USA	1994 or later	1/1/2006	No	Yes	No	No	Yes
1078 Dogwood Rd, Heber, CA	1994 or later	1/1/2006	No	Yes	Yes	No	Yes
299 S Reservation Rd, Porterville, CA, 93257, USA	1994 or later	1/1/2006	No	Yes	No	No	Yes
33485 Valley Center Rd, Valley Center, CA, 92082, USA	1994 or later	1/1/2006	No	Yes	Yes	No	Yes
12137 Highway 3, Fort Jones, CA 96032	1994 or later	1/1/2006	No	Yes	No	No	No
43033 CA-49, Ahwahnee, CA 93601	1994 or later	1/1/2006	No	Yes	No	No	No
6002 Camino Rico, San Diego, CA, 92120, USA	1994 or later	5/29/2006	No	Yes	No	No	Yes
41450 Sand Creek Rd, Squaw Valley, CA, 93675, USA	1994 or later	9/24/2006	No	Yes	No	No	No
790 N Temperance Ave, Clovis, CA, 93611, USA	1994 or later	9/24/2006	No	Yes	No	No	No
7649 Sterling Ave, San Bernardino, CA, 92410, USA	1994 or later	10/3/2006	No	Yes	No	No	No
1832 Decker Canyon Rd, Malibu, CA, 90265, USA	1994 or later	10/24/2006	No	Yes	No	No	Yes
29575 Canwood St, Agoura Hills, CA, 91301, USA	1994 or later	10/24/2006	No	Yes	No	No	Yes
34951 Road 606, Raymond, CA, 93653, USA	1994 or later	11/15/2006	No	Yes	No	No	Yes
13050 Soda Lake Rd, Santa Margarita, CA, 93453, USA	1994 or later	1/1/2007	No	Yes	No	No	No
1005 N Gaffey St, San Pedro, CA, 90731, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
3690 Motor Ave, Los Angeles, CA, 90034, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
11970 Venice Blvd, Los Angeles, CA, 90066, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
5451 Playa Vista Dr, Playa Vista, CA, 90094, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
14335 Arminta St, Panorama City, CA, 91402, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
21050 Burbank Blvd, Woodland Hills, CA, 91367, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
10124 Balboa Blvd, Granada Hills, CA, 91344, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
11617 Arminta St, North Hollywood, CA, 91605, USA	1994 or later	1/1/2007	No	Yes	No	No	Yes
6041 Edgewood Bend Ct, San Diego, CA, 92130, USA	1994 or later	1/1/2007	No	No	No	No	Yes
3078 W Orange Ave, Anaheim, CA, 92804, USA	1994 or later	1/1/2007	No	Yes	No	No	No
24241 Avila Rd, Laguna Niguel, CA, 92677, USA	1994 or later	1/1/2007	No	Yes	No	No	
250 E Park St, Independence, CA, 93526, USA	1994 or later	1/1/2007	No	Yes	No	No	No
39582 Balch Park Rd, Springville, CA, 93265, USA	1994 or later	1/1/2007	No	Yes	No	No	No
633 Pollasky Ave, Clovis, CA, 93612, USA	1994 or later	1/1/2007	No	Yes	No	No	No
47625 Mines Rd, Livermore, CA, 94550, USA	1994 or later	10/16/2007	No	Yes	No	No	No
4301 South Santa Fe Avenue, Vernon, California 90058	1994 or later	11/13/2007	No	Yes	No	No	No
37900 Highway 36E, Mineral, CA	1994 or later	1/1/2008	No	Yes	No	No	No
3500 Harris Grade Rd, Lompoc, CA, 93436, USA	1994 or later	1/1/2008	No	Yes	No	Yes	
5815 Mountain Vista Dr, Bakersfield, CA 93311	1994 or later	1/1/2008	No	Yes	No	No	Yes
1192 E 51st St, Los Angeles, CA, 90011, USA	1994 or later	1/1/2008	No	Yes	No	No	Yes
4041 Whitsett Ave, Studio City, CA, 91604, USA	1994 or later	1/1/2008	No	Yes	No	No	Yes

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
5300 Olive Ranch Rd, Granite Bay, CA, 95746, USA	1994 or later	1/1/2008	No	Yes	No	No	No
11855 Pacific Coast Highway, Malibu, CA, 90265, USA	1994 or later	1/1/2008	No	Yes	No	No	No
3410 Dye Rd, Ramona, CA, 92065, USA	1994 or later	1/1/2008	No	Yes	No	No	No
3 Berry Creek Rd, Berry Creek, CA, 95916, USA	1994 or later	1/1/2008	No	Yes	No	No	No
29300 Dew Drop Rd, Pioneer, CA 95666	1994 or later	1/1/2008	No	Yes	No	No	No
2323 Felicita Rd, Escondido, CA, 92029, USA	1994 or later	1/1/2008	No	Yes	No	No	No
5362 Platt Mountain Rd, Forest Ranch, CA, 95942, USA	1994 or later	1/1/2008	No	Yes	No	No	No
2323 Felicita Rd, Escondido, CA, 92029, USA	1994 or later	1/1/2008	No	Yes	No	No	No
29300 Dew Drop Bypass, Pioneer, CA, 95666, USA	1994 or later	1/1/2008	No	Yes	No	No	No
3606 Hendrix Dr, Stockton, CA, 95212, USA	1994 or later	5/13/2008	No	Yes	Yes	No	No
1010 Pauma Reservation Rd, Pauma Valley, CA, 92061, USA	1994 or later	8/28/2008	No	Yes	No	No	Yes
7540 Oro Bangor Hwy, Marysville, CA, 95901, USA	1994 or later	10/6/2008	No	Yes	No	No	No
28799 Rock Canyon Dr, Santa Clarita, CA, 91390, USA	1994 or later	10/10/2008	No	No	No	No	No
5624 E Avenue R, Palmdale, CA, 93552, USA	1994 or later	10/10/2008	No	Yes	No	No	No
450 Pioneer Ave, Nipomo, CA, 93444, USA	1994 or later	10/11/2008	No	Yes	No	No	Yes
3650 Bolz Ranch Rd, Palmdale, CA, 93551, USA	1994 or later	10/29/2008	No	Yes	No	No	Yes
1270 W Park Ave, Redlands, CA, 92373, USA	1994 or later	11/14/2008	No	Yes	No	No	Yes
2629 CA-49, Mariposa, CA, 95338, USA	1994 or later	11/15/2008	No	Yes	No	No	No
14024 Peaceful Valley Ranch Rd, Jamul, CA, 91935, USA	1994 or later	1/1/2009	No	Yes	No	No	Yes
10811 S Main St, Los Angeles, CA, 90061, USA	1994 or later	1/1/2009	No	Yes	No	No	Yes
150 Ohleyer Rd, Yuba City, CA, 95993, USA	1994 or later	1/1/2009	No	Yes	Yes	No	No
34400 CA-3, Weaverville, CA 96093	1994 or later	1/1/2009	No	Yes	No	No	Yes
39939 170th St E, Palmdale, CA, 93591, USA	1994 or later	10/10/2009	No	Yes	No	No	No
4671 Broad St, San Luis Obispo, CA, 93401, USA	1994 or later	10/18/2009	No	Yes	No	No	No
11600 Columbia College Dr, Sonora, CA, 95370, USA	1994 or later	1/1/2010	No	Yes	No	No	No
12280 Pacheco Pass Hwy, Hollister, CA, 95023, USA	1994 or later	1/1/2010	No	Yes	No	No	No
22978 Meadow Ln, Twain Harte, CA, 95383, USA	1994 or later	9/24/2010	No	Yes	No	No	No
45360 Lucky Baldwin Ranch Rd, Big Bear City, CA, 92314, USA	1994 or later	10/5/2010	No	Yes	No	No	No
6055 Webster Rd, Creston, CA 93432	1994 or later	10/10/2010	No	Yes	No	No	No
13540 S. Beach Blvd. La Mirada, CA 90638	1994 or later	10/17/2010	No	Yes	No	No	No
5003 Depot Ave, Santa Maria, CA, 93454, USA	1994 or later	1/1/2011	No	Yes	No	No	No
3000 S Hoover St, Los Angeles, CA, 90007, USA	1994 or later	1/1/2011	No	Yes	No	No	Yes
31 27th Ave, San Mateo, CA, 94403, USA	1994 or later	1/1/2011	No	Yes	Yes	No	Yes
3939 Avenue 54, Alpaugh, CA, 93201, USA	1994 or later	1/1/2011	No	Yes	No	No	No
3860 Ponderosa Rd, Shingle Springs, CA, 95682, USA	1994 or later	1/1/2011	No	Yes	No	No	Yes
2383 Honeysprings Rd, Jamul, CA 91935	1994 or later	1/1/2011	No	Yes	No	No	Yes
35227 Highway 79, Warner Springs, CA 92086	1994 or later	1/1/2011	No	Yes	No	No	Yes
5874 E Los Angeles Ave, Simi Valley, CA, 93063, USA	1994 or later	1/1/2011	No	Yes	Yes	No	No
38333 Road 223, Oakhurst, CA 93644	1994 or later	1/1/2011	No	Yes	No	No	No
24505 Copper Hill Dr, Valencia, CA, 91354, USA	1994 or later	10/10/2011	No	Yes	No	No	No
7250 World Way W, Los Angeles, CA, 90045, USA	1994 or later	1/1/2012	No	Yes	No	No	Yes
5769 Hollywood Blvd, Los Angeles, CA, 90028, USA	1994 or later	1/1/2012	No	Yes	No	No	Yes
222 Fairway Dr, Tahoe City, CA, 96145, USA	1994 or later	1/1/2012	No	Yes	Yes	No	Yes
29690 Oak Dr, Campo, CA 91906	1994 or later	1/1/2012	No	Yes	No	No	Yes
37370 Montezuma Valley Road, Ranchita, CA 92066	1994 or later	1/1/2012	No	Yes	No	No	Yes
7260 Great Southern Overland, Julian, CA 92036	1994 or later	1/1/2012	No	Yes	No	No	Yes
2901 Erringer Rd, Simi Valley, CA, 93065, USA	1994 or later	1/1/2012	No	Yes	No	No	No
31049 Highway 79, Warner Springs, CA, 92086, USA	1994 or later	1/1/2012	No	Yes	No	No	Yes
697-345 CA 36, Susanville, CA 96130	1994 or later	1/1/2012	No	Yes	No	No	No
10242 Ridge Rd, Nevada City, CA, 95959, USA	1994 or later	1/1/2012	No	Yes	No	No	No
410 School St, Point Arena, CA, 95468, USA	1994 or later	1/1/2012	No	Yes	No	No	No
3288 Rd 308, Elk Creek, CA 95939	1994 or later	1/1/2012	No	Yes	No	No	No
11787 Ponderosa Way, Whitmore, CA 96096	1994 or later	10/2/2012	No	Yes	No	No	Yes
1001 S Cloverdale Blvd, Cloverdale, CA, 95425, USA	1994 or later	10/2/2012	No	Yes	No	No	No
16001 Highway 128, Boonville, CA, 95415, USA	1994 or later	10/12/2012	No	Yes	Yes	No	No
2142 Sperry Ave, Patterson, CA, 95363, USA	1994 or later	10/16/2012	No	Yes	No	No	Yes
28450 Whites Canyon Rd, Canyon Country, CA, 91351, USA	1994 or later	10/16/2012	No	Yes	No	No	No
29310 Sand Canyon Rd, Canyon Country, CA, 91387, USA	1994 or later	10/16/2012	No	Yes	No	No	No
4470 Coliseum St, Los Angeles, CA, 90016, USA	1994 or later	1/1/2013	No	Yes	No	No	Yes
14024 Peaceful Valley Ranch Rd, Jamul, CA 91935	1994 or later	1/1/2013	No	Yes	No	No	Yes
15011 Kensington Park Dr, Tustin, CA 92782	1994 or later	1/1/2013	No	Yes	No	No	
24020 Fowler Ave, Colfax, CA, 95713, USA	1994 or later	1/1/2013	No	Yes	No	No	No
3250 Highway 128, Geyserville, CA, 95441, USA	1994 or later	1/1/2013	No	Yes	Yes	No	Yes
125 N Main St, Angels Camp, CA, 95222, USA	1994 or later	9/25/2013	No	Yes	No	No	No
34520 Engineers Rd, Julian, CA, 92036, USA	1994 or later	9/26/2013	No	Yes	No	No	No
19190 Golden Valley Rd, Canyon Country, CA, 91387, USA	1994 or later	10/16/2013	No	Yes	No	No	No
319 S Humboldt St, San Mateo, CA, 94401, USA	1994 or later	1/1/2014	No	Yes	No	No	Yes
551 Harbison Canyon Rd, El Cajon, CA 92019	1994 or later	5/30/2014	No	Yes	No	No	Yes
37370 Montezuma Valley Rd, Ranchita, CA, 92066, USA	1994 or later	9/27/2014	No	Yes	No	No	No
28722 Pacific Coast Hwy, Malibu, CA, 90265, USA	1994 or later	10/24/2014	No	Yes	No	No	Yes
9366 Friars Rd, San Diego, CA, 92108, USA	1994 or later	1/1/2015	No	No	No	No	Yes
7180 Skyline Dr, San Diego, CA, 92114, USA	1994 or later	1/1/2015	No	Yes	No	No	Yes
980 S Jaye St, Porterville, CA, 93257, USA	1994 or later	1/1/2015	No	Yes	No	No	No
370 Newton Rd, Weott, CA, 95571, USA	1994 or later	1/1/2015	No	Yes	No	No	No
40080 Ribbonwood Road, Boulevard, Ca, 91905	1994 or later	5/30/2015	No	Yes	No	No	Yes
846 E. Juniper Ridge Azusa, CA 91702	1994 or later	11/25/2015	No	Yes	No	No	No
1919 Cordoba St, Livermore, CA, 94550, USA	1994 or later	1/1/2016	No	Yes	No	No	No
40080 Ribbonwood Rd, Boulevard, CA, 91905, USA	1994 or later	1/1/2016	No	Yes	Yes	No	No
13298 Briceland Thorn Rd, Whitethorn, CA, 95589, USA	1994 or later	1/1/2016	No	Yes	No	No	No
38737 Kneeland Rd, Bridgeville, CA, 95526, USA	1994 or later	1/19/2016	No	Yes	Yes	No	No
60 Fawn Lodge Rd, Lewiston, CA 96052	1994 or later	10/2/2016	No	Yes	No	No	Yes
28580 Hasley Canyon Rd, Castaic, CA, 91384, USA	1994 or later	10/18/2016	No	Yes	No	No	No
1625 Buena Vista Ave, Alameda, CA, 94501, USA	1994 or later	1/1/2017	No	Yes	Yes	No	No
2256 Cleveland Ave, Thermal, CA, 92274, USA	1994 or later	1/1/2017	No	Yes	No	No	No
3407 Highway 79, Julian, CA 92036	1994 or later	1/1/2017	No	Yes	No	No	Yes

Fire Station address	Fire Station Construction Year	Please provide the exact construction year:	Has a Seismic Retrofit been performed?	Does this station provide Emergency Medical Services (EMS)?	Is this station designated as a local Emergency Operations Center (EOC)?	Have you installed Earthquake Early Warning (EEW) System/ Technology?	Would you be interested in learning more about the EEW technology and funding opportunities?
751 Mitchell Rd, Thousand Oaks, CA, 91320, USA	1994 or later	1/1/2017	No	Yes	No	No	No
4206 Chamoune Ave, San Diego, CA, 92115, USA	1994 or later	5/29/2017	No	Yes	No	No	Yes
518 Railroad Ave, Winterhaven, CA, 92283, USA	1994 or later	1/1/2018	No	Yes	No	No	Yes
875 W Cedar St, San Diego, CA, 92101, USA	1994 or later	1/1/2018	No	No	No	No	Yes
3902 9th Ave, San Diego, CA, 92103, USA	1994 or later	1/1/2018	No	No	No	No	Yes
28850 Old Highway 80, Pine Valley, CA, 91962, USA	1994 or later	1/1/2018	No	Yes	No	No	Yes
1055 Catalina Blvd, San Diego, CA, 92107, USA	1994 or later	5/29/2018	No	Yes	No	No	Yes
2540 E La Palma Ave, Anaheim, CA, 92806, USA	1994 or later	5/30/2018	No	No	No	No	No
753 Las Posadas Rd, Angwin, CA, 94508, USA	1994 or later	10/5/2018	No	No	No	No	No
14615 Oxnard St, Van Nuys, CA, 91411, USA	1994 or later	1/1/2019	No	Yes	No	No	Yes
133 C St, Fillmore, CA, 93015, USA	1994 or later	1/1/2019	No	Yes	No	No	No
17290 Skyline Blvd, Woodside, CA, 94062, USA	1994 or later	6/13/2019	No	Yes	No	No	No
28850 Old Highway 80, Pine Valley, CA, 91962, USA	1994 or later	10/5/2019	No	Yes	No	No	No
2510 Ramada Dr, Paso Robles, CA, 93446, USA	1941 or Prior	1/1/2020	No	Yes	No	No	
25456 Road 140, Tulare, CA, 93274, USA	1994 or later	1/1/2020	No	Yes	No	No	No
7177 Shoreline Dr, San Diego, CA, 92122, USA	1994 or later	1/1/2020	No	Yes	No	No	Yes
176 Nelson Ave, Oroville, CA, 95965, USA	1994 or later	1/1/2020	No	Yes	Yes	No	No
12137 N. Main St., Fort Jones, CA 96032	1994 or later	1/1/2020	No	Yes	No	No	No
26901 Golden Valley Rd, Santa Clarita, CA, 91350, USA	1994 or later	10/16/2020	No	Yes	No	No	No
1455 Shafter St, San Mateo, CA, 94402, USA	1994 or later	1/1/2021	No	Yes	No	No	Yes
8071 Luxor Ave, Niland, CA, 92257, USA	1994 or later	1/1/2021	No	Yes	Yes	No	Yes
12727 Santa Paula Ojai Road, Santa Paula, CA 93060	1994 or later	1/1/2021	No	Yes	No	No	No
555 Obispo Rd, El Granada, CA, 94018, USA	1994 or later	1/1/2021	No	Yes	No	No	No
463-700 Mooney Road, Westwood, CA 96137	1994 or later	1/1/2021	No	Yes	No	No	No
Luxor Ave, Niland, CA, 92257, USA	1994 or later	5/24/2021	No	Yes	Yes	No	Yes
21610 Crestline Rd, Palomar Mountain, CA, 92060, USA	1994 or later	1/1/2022	No	Yes	Yes	No	No
3200 Santa Rita Rd, Pleasanton, CA, 94566, USA	1994 or later	1/1/2022	No	Yes	No	No	No
33947 Mount Laguna Dr, Pine Valley, CA, 91962, USA	1994 or later	1/1/2022	No	Yes	No	No	No
33947 Mount Laguna Dr, Mt Laguna, CA 91948	1994 or later	5/30/2022	No	Yes	No	No	Yes
2388 Encino Avenue, Clovis, CA, 93619, USA	1994 or later	9/24/2022	No	Yes	No	No	No
19850 Riverside Ave, Anderson, CA 96007	1994 or later	10/2/2022	No	Yes	No	No	Yes
1400 Manhattan Beach Blvd, Manhattan Beach, CA, 90266, USA	1994 or later	1/1/2023	No	Yes	No	No	No
15339 Skylan Ln, Prather, CA, 93651, USA	1994 or later	1/1/2023	No	Yes	No	No	Yes
850 Alta Rd, San Diego, CA, 92154, USA	1994 or later	1/1/2023	No	Yes	No	No	Yes
108 Chaney Ave, Cayucos, CA 93430	1994 or later	1/1/2023	No	Yes	No	Yes	
850 Alta Rd, San Diego, CA, 92154, USA	1994 or later	1/1/2023	No	Yes	No	No	No
38700 Hot Springs Dr, California Hot Springs, CA, 93207, USA	1994 or later	9/25/2023	No	Yes	No	No	No
41 Newsome St, New Cuyama, CA, 93254, USA	1994 or later	1/1/2024	No	Yes	No	No	No
San Luis Obispo, CA, USA	1994 or later	1/1/2024	No	Yes	No	No	No
2300 Minnewawa Ave, Clovis, CA, 93612, USA	1994 or later	1/1/2024	No	Yes	No	No	No
10281 N Torrey Pines Rd, La Jolla, CA, 92093, USA	1994 or later	5/30/2024	No	No	No	No	Yes
320 S Los Carneros Rd, Goleta, CA, 93117, USA	1941 - 1973	1/1/8082	No	Yes	No	No	No

Appendix B


Fire Hazard Severity Zones
August 04 2025
Medford
Phase 1, as recommended on February 10, 2025
Carson City
Sacramento
Phase 2, as recommended on February 24, 2025
San Jose
Fresno
CALIFORNIA
Phase 3, as recommended on March 10, 2025
Las Vegas
Phase 4, as recommended on March 24, 2025
Los Angeles
San Diego
Tijuana
Mexicali
Fire Station
Fire Station
California State Responsibility Areas
Local Responsibility Area (LRA)
State Responsibility Area (SRA)
Federal Responsibility Area (FRA)
FHSZ Rollout Phases
Phase 1
Phase 2
Phase 3
Phase 4
Fire Hazard Severity Zones in State Responsibility Area
Very High
High
Moderate
Fire Hazard Severity Zones in Local Responsibility Area
Very High
High
Moderate
0 50 100 150
Miles

Appendix C

CALIFORNIA GOVERNOR'S OFFICE OF EMERGENCY SERVICES
INSTRUCTIONS FOR
STATEWIDE SURVEY OF FIRE STATION SEISMIC VULNERABILITIES

GENERAL INSTRUCTIONS

- This survey is built utilizing ESRI's ArcGIS Survey 123 for ArcGIS.
    - No password is required. You may leave and return to the survey; however, you must use the same browser, or your cached responses may be lost. Also, be sure to use the Back and Next buttons to navigate rather than using the browser arrows.
- The survey is located here: https://arcg.is/0izu9e.
- For clarification on any questions or for technical issues, please complete a Help Request form.
- Items with a * in the survey are mandatory fields. A response must be provided.

PAGE 1: INTRODUCTION

- Please review, note the Help Request form, and click "Next". If the survey opens to page 1 automatically, please click the back button on page 1 to see the introductory page.

PAGE 2: LOCATION AND CONTACT INFORMATION

- **Address questions**
    - Please enter the same address for the first two questions. The first entry will provide a mapping location (LAT, LONG) and the second will provide all address fields. Please be sure to click on the fire station building to ensure we are getting an exact location and the station's building footprints. You may need to zoom in using CTRL + Scroll or "+" to pin the fire station building.
- **Enter the FDID**
    - This should be a 5-digit number. Please utilize the ResponseRack resource if you need to look up the Fire Department Identification (FDID) Code.
- **Enter Fire Station Building ID**
    - This will typically be the fire station number. If the station does not have a number, then please enter 0.


- **Contact First and Last Name and Email Address**
    - To be used if we have follow-up questions or need clarification on a response.
- **Contact Phone Number**
    - Be sure only to enter numbers. The system will format.

PAGE 3: BUILDING TYPE, CLASSIFICATION, AND PROPERTIES

- **Date of Construction of Fire Station (Range and Exact Year)**
    - If unsure of the year of construction, to report a range, or for providing an exact year, please be sure to contact your local building official, public works department, or engineer of record to confirm.
- **Fire Station Number of Stories and Roof Height**
    - Please select based on the highest story of the fire station, not the administration building, if it is attached. For the roof height in feet, use the average roof height and round to the nearest whole number. The roof height will be used to develop other key measurements of the building.
- **Addition/ Remodel Questions**
    - Please think about and only provide the latest addition/remodel information.
- **Seismic Retrofit Questions**
    - Please think about and only provide the latest retrofit project information.
- **FEMA Building Type**
    - Please reference these diagrams to better understand and report the building type for the Fire Station that is being reported. Please be sure to contact your local building official, public works department, or engineer of record to confirm your selection:

CONCRETE TYPES - C1, C2, C3

FEMA Building Type C1 CONCRETE MOMENT FRAMES




These buildings consist of concrete framing, either a complete system of beams and columns or columns supporting slabs without gravity beams. Lateral forces are resisted by moment frames that develop stiffness through rigid connections of the column and beams placed in a given bay. Moment frames may be developed on all framing lines or only in selected bays. It is significant that no structural walls are required. Floors are cast-in-place or precast concrete. Buildings with concrete moment frames could be used for most occupancies listed for steel moment frames, but are also used for multistory residential buildings.

The C1A building type is similar but has floors and roof that act as flexible diaphragms, such as wood or uptopped metal deck. This is a relatively unusual building type, but might be found as older warehouse-type buildings or small office occupancies.

FEMA Building Type C2 CONCRETE SHEAR WALLS

with bearing walls




Concrete shear walls are concrete walls in a building design to provide lateral stiffness and strength for lateral loads. There are two main types of shear-wall buildings, those in which the shear walls also carry the gravity loads (with bearing walls), and those in which a column-supported framing system carries the gravity loads (with gravity frame).

In the **bearing wall** type, all walls usually act as both bearing and shear walls. The building type is similar and often used in the same occupancies as type RM2, namely in mid- and low-rise hotels and motels. This building type is also used in residential apartment/condo-type buildings.


In **gravity frame** buildings, shear walls are either strategically placed around the plan, or at the perimeter. Shear-wall systems placed around the entire perimeter must contain the windows, and other perimeter openings are called punched shear walls. These buildings were commonly built in the 1950s and 1960s for a wide variety of most institutional occupancy types.

with gravity frames



The C2A building type is similar, but has floors and roof that act as flexible diaphragms such as wood, or uptopped metal deck. C2A buildings are normally bearing-wall buildings. These buildings are similar to building-type RM1 and are used for similar occupancies- such as small office or commercial and sometimes residential.

FEMA Building Type C3 CONCRETE FRAMES with infill masonry shear walls




These buildings consist of concrete framing, either a complete system of beams and columns or columns supporting slabs without gravity beams. Exterior walls and possibly some interior walls are constructed of unreinforced solid clay brick, concrete block, or hollow clay tile masonry infilling the space between columns and beams. Windows and doors may be present in the infill walls, but to act effectively as shear-resisting elements, the infill masonry must be constructed tightly against the columns and beams. The building type is similar to S5, but is more often used for industrial and warehouse occupancies.

The C3A building type is similar but has floors and roof that act as flexible diaphragms, such as wood, or uptopped metal deck. Thisbuilding type not often found except as one-story industrial buildings.

PRE-CAST CONCRETE TYPES - PC1, PC2


FEMA Building Type PC1 TILT-UP CONCRETE shear walls



These buildings are constructed with perimeter concrete walls precast on the site and tilted up to form the exterior of the buildings, to support all or a portion of the perimeter roof load, and to provide seismic shear resistance. These buildings are commonly one-story with a wood joist and plywood roof or sometimes with a roof of steel joists and metal deck. Two-story tilt-ups usually have a steel-framed second floor with metal deck and concrete and a wood roof. Tilt-up walls that support roof load are very common on the West Coast; due to economical construction cost, they are used for many occupancies, including warehouses, retail stores, and offices. In other parts of the country, these buildings more often have an independent load-carrying system on the inside face of the walls.

The PC1A building is similar but features all floors and/or roof constructed of materials that form a rigid diaphragm, normally concrete. This building type is similar to PC2.

FEMA Building Type PC2 PRECAST CONCRETE FRAMES with shear walls




These buildings consist of concrete columns, girders, beams and/or slabs that are precast off the site and erected to form a complete gravity-load system. Type PC2 has a lateral force-resisting system of concrete shear walls, usually cast-in-place. Many garages have been built with this system. The building type is most common in moderate and low seismic zones and could be used for many different occupancies in those areas.

The PC2A building is similar but obtains lateral support from specially connected precast girders and columns that form moment frames. Until recently, precast moment frames have not been allowed in regions of high seismicity, and these buildings will essentially only be found in moderate or low seismic zones.


MASONRY TYPES - RM1, RM2, URM

FEMA Building Type RM1 REINFORCED MASONRY WALLS with flexible diaphrams



These buildings take a variety of configurations, but they are characterized by reinforced masonry walls (brick cavity wall or CMU) with flexible diaphragms, such as wood or metal deck. The walls are commonly bearing, but the gravity system often also contains post-and-beam construction of wood or steel. Older buildings of this type are generally small and were used for a wide variety of occupancies and are configured to suit. Recently, the building type is commonly used for one-story warehouse-type occupancies similar to tilt-up buildings.


FEMA Building Type RM2 REINFORCED MASONRY WALLS with stiff diaphrams



This building consists of reinforced masonry walls and concrete slab floors that may be either cast-in-place or precast. This building type is often used for hotel and motels and is similar to the concrete bearing-wall type C2.

FEMA Building Type URM UNREINFORCED MASONRY BEARING WALLS

2-4 wythe brick masonry exterior bearing walls



This building consists of unreinforced masonry bearing walls, usually at the perimeter and usually brick masonry. The floors are wood joists and wood sheathing supported on the walls and on interior post-and-beam construction or wood-stud bearing walls. This building type is ubiquitous in the U.S. and was built for a wide variety of uses, from one-story commercial or industrial occupancies, to multistory warehouses, to mid-rise hotels. Unfortunately, it has consistently performed poorly in earthquakes. The most common failure is an outward collapse of the exterior walls, caused by loss of lateral support due to separation of the walls from the floor/roof diaphragm.

The URMA building is similar, but features all floors and/or roof constructed of materials that form a rigid diaphragm, usually concrete slabs or steel joists with flat-arched unreinforced masonry.

STEEL TYPES - S1, S2, S3, S4, S5


FEMA Building Type S1 STEEL MOMENT FRAMES



These buildings consist of an essentially complete frame assembly of steel beams and columns. Lateral forces are resisted by moment frames that develop stiffness through rigid connections of the beam and column created by angles, plates and bolts, or by welding. Moment frames may be developed on all framing lines or only in selected bays. It is significant that no structural walls are required. Floors are cast-in-place concrete slabs or metal deck and concrete. This building is used for a wide variety of occupancies such as offices, hospitals, laboratories, and academic and government buildings.

The S1A building type is similar but has floors and roof that act as flexible diaphragms, such as wood or uptopped metal deck. One family of these buildings are older warehouse or industrial buildings, while another more recent use is for small office or commercial buildings in which the fire rating of concrete floors is not needed.


FEMA Building Type S2 STEEL-BRACED FRAMES



These buildings consist of a frame assembly of steel columns and beams. Lateral forces are resisted by diagonal steel members placed in selected bays. Floors are cast-in-place concrete slabs or metal deck and concrete. These buildings are typically used for buildings similar tos teel-moment frames, although are more often low rise.


The S2A building type is similar but has floors and roof that act as flexible diaphragms such as wood, or uptopped metal deck. This is a relatively uncommon building type and is used mostly for smaller office or commercial buildings in which the fire rating of concrete floor is not needed.

FEMA Building Type S3 STEEL LIGHT FRAMES




These buildings are one story, pre-engineered and partially prefabricated, and normally consist of transverse steel bents and light purlins. The roof and walls consist of lightweight metal, fiberglass, or cementitious panels. Lateral forces are resisted by the transverse steel bents acting as moment frames, and light rod diagonal bracing in the longitudinal direction. The roof diaphragm is either metal deck or diagonal rod bracing. These buildings are mostly used for industrial or agricultural occupancies.

FEMA Building Type S4 STEEL FRAMES with concrete shearwalls



These buildings consist of an essentially complete frame assembly of steel beams and steel columns. The floors are concrete slabs or concrete fill over metal deck. The buildings feature a significant number of concrete walls effectively acting as shear walls, either as vertical transportation cores, isolated in selected bays, or as a perimeter wall system. The steel column-and-beam system may act only to carry gravity loads or may have rigid connections to act as a moment frame. This building type is generally used as an alternate for steel moment or braced frames in similar circumstances. These buildings will usually be mid- or low-rise.


FEMA Building Type S5 STEEL FRAMES with infill masonry walls





This is normally an older building that consists of an essentially complete frame assembly of steel floor beams or trusses and steel columns. The floor consists of masonry flat arches, concrete slabs or metal deck, and concrete fill. Exterior walls and possibly some interior walls, are constructed of unreinforced solid clay brick, concrete block, or hollow-clay tile masonry infilling the space between columns and beams. Windows and doors may be present in the infill walls, but to act effectively as shear-resisting elements, the infill masonry must be constructed tightly against the columns and beams. Although relatively modern buildings in moderate or low seismic regions are built with unreinforced masonry exterior infill walls, the walls are generally not built tight against the beams and columns and therefore do not provide shear resistance. The buildings intended to fall into this category feature exposed clay brick masonry on the exterior and are common in commercial areas of cities with occupancies of retail stores, small offices, and hotels.

The S5A building type is similar but has floors and roof that act as flexible diaphragms, such as wood or uptopped metal deck. These buildings will almost all date to the 1930s and earlier, and were originally warehouses or industrial buildings.

WOOD TYPES – W1, W1A, W2







- **Building Foundation Type – Deep Pile?**
  - *Definition:* A Pile foundation is typically characterized by a vertical or nearly vertical element (the pile) embedded directly into the ground. This element transfers the weight of a structure into the ground through either friction between the pile sides and the surrounding soil or end bearing of the pile against stiff soils and rock beneath it.
- **Building Floor Area**
  - Please be sure to add all square footage from any attached administrative buildings.
- **Building Plan Configuration**
- **Fire Station Setting Classification**
  - An urban setting for the purposes of this classification is defined as serving 50,000 or more people in the service area.
- **Number of Fire Engines**
  - Please only report on the total number of fire engines.
- **Approximate Population Served**
  - For consistent results, please use the U.S. Census Bureau Quick Facts site and enter your city/town and state if the population is 5,000 or more.
- **Seasonal Fire Station Questions**
  - Please think of a typical year and whether the station functions all 12 months. If it fluctuates, please enter the median number of months based on the past 3 years.
- **Approximate Day Occupants**
  - While the population may vary from day to day, please consider a typical workday in a non-emergency status at 2:00 p.m. PST. This number includes sworn firefighters and civilian staff.
- **Approximate Evening Occupants**
  - While the population may vary from day to day, please consider a typical evening in a non-emergency status at 2:00 a.m. PST. This number includes sworn firefighters and any civilian staff.
- **Distance to next closest fire station**
  - Please be sure to report a number only. Miles will be assumed. If entering a decimal number, please only enter to the tenths (e.g., .7).
- **EMS Questions**
  - If you are reporting that EMS is offered for the station, such as BLS or ALS, please note that the distance to the closest EMS station question is for any EMS offered and that miles will be assumed. Again, if entering a decimal, please only enter to the tenths (e.g., .7).
- **Local EOC Question**

PAGE 4: BACK-UP POWER SYSTEMS

- **What is the fuel source of your primary backup power source?**
  - o Please report on only the primary source of fuel for the main backup power source.
- **Amount of emergency fuel on-site for the primary source.**
  - o This should be consistent with the previous question and a snapshot at the time of completing this survey.
- **Estimate of days of emergency fuel for the primary source.**
  - o This should be consistent with the amount of fuel reported and a snapshot taken at the time of survey completion. Please enter the estimate as a decimal if it is less than a day (e.g., 0.5 for 12 hours or half a day).

PAGE 5: APPARATUS DOORS

- **Number of Apparatus Bays**
- **Height of tallest apparatus doors**
  - Please be sure to report the closest number of inches for a typical apparatus door.
- **Year of Installation of the oldest Apparatus Door**
  - Please provide the date of the latest installation, considering all apparatus doors.
- **Apparatus Door Material(s)**
  - Please provide information for each of the front and rear apparatus doors. There should be a response for all doors. Use "Not Applicable" if fewer doors than listed.
- **Apparatus Door Type(s)**
  - Please provide information for each of the apparatus doors. There should be a response for all doors. Use "Not Applicable" if fewer doors than listed.
- **Are door motors connected to emergency power?**
  - Please provide information for each of the apparatus doors. There should be a response for all doors. Use "No" if fewer doors than listed.
- **Overall Apparatus Door Conditions**
  - Please report all selections that apply across all doors reported.
- **Earthquake Early Warning (EEW) System/ Technology?**
  - This question refers to technology available for fire stations that have been installed in a few select stations. If you express interest, you will be provided additional information and possibly contacted to discuss the program and requirements

PAGE 6: PHOTOS

- Please ensure all photos are at least 300 dpi. Most formats will be accepted, including BMP, GIF, JPEG, RAW, and TIFF. If possible, please label each photograph with the station name and a clear view (e.g., Front view, Rear view, Side 1 view, etc.). Also, try to capture as much of the building as possible in each outdoor photo. Please note the minimum resolution of 300 dpi and the maximum file size of 10 MB again.

PAGE 7: ADDITIONAL COMMENTS, INSIGHTS, OR NOTES

- Please add any information or explanation that will help review responses or provide additional insights that may help to clarify a response.

CONCLUSION AND SUBMISSION

You have now completed this Cal OES Statewide Fire Station Survey for Potential Seismic Vulnerabilities.

Please click the submit button to submit your survey. You may click the back button to review and make changes to any entries or seek clarification using the Help Request form at any time before submission.

Appendix D

Funding Source Details and Supplemental Notes

This appendix provides expanded descriptions, citations, and clarifications for select funding sources referenced in Section 5. It is intended for technical reviewers and decision-makers who require additional context on program mechanics, eligibility nuances, and recent developments.

FEMA Hazard Mitigation Grant Program (HMGP)

- Allocations vary by disaster scale, using a tiered formula (up to 20% for Enhanced Plans).
- Eligible activities include seismic retrofitting, equipment anchoring, and EEW infrastructure when integrated into FEMA-approved hazard mitigation plans.
- EEW-related activities are exempt from cost-effectiveness requirements when involving seismic networks, geodetic networks, or sensor infrastructure.
- In California, HMGP is administered by Cal OES, which oversees application intake, project review, and coordination with FEMA.
- Ongoing maintenance and operational costs are not eligible.

  Website: FEMA Hazard Mitigation Grant Program (HMGP)

NEHRP State Assistance Program (ISEA and MSNEA)

- Supports seismic risk reduction through planning, code updates, vulnerability assessments, and public education.
- Fire station retrofitting is eligible under ISEA when aligned with hazard mitigation plans.
- EEW integration is supported for planning and coordination, not for infrastructure buildout or maintenance and operations.
- FY 2025 national funding totaled $2.09 million, with awards ranging from $50,000 to $963,000.

Website: NEHRP State Assistance Program (ISEA and MSNEA)

Cal OES EEW Implementation Pilot Grant for Fire Stations

- Launched in April 2024 to support EEW integration in fire stations.
- Performance period: June 1, 2024 – December 31, 2025.
- This was a one-time grant; future rounds are not guaranteed.

Website: Earthquake Warning California Legislative Report

FEMA Pre-Disaster Mitigation (PDM) Grant Program

- Granted through CDS requests and subject to federal appropriations, this program funds proactive hazard mitigation projects, including seismic retrofitting and EEW integration.
- EEW eligibility confirmed through FEMA's EEW Fact Sheet and CRS ShakeAlert report.
- FY 2024: $190.5 million allocated; 110 projects funded.
- Standard cost share: 75% federal / 25% non-federal; up to 90% for small or Tribal communities.

Websites:

- FEMA PDM Overview: Pre-Disaster Mitigation (PDM) Grant Program
- CRS ShakeAlert Report: Congressional Research Service ShakeAlert Report

HUD Community Development Block Grant (CDBG)

- Supports public facility improvements in low- and moderate-income communities.
- Fire station retrofits may qualify under 24 CFR §570.201(c) if they serve a qualifying public purpose.
- EEW infrastructure is not eligible but planning and education efforts may be.
- Local demographics and national objectives determine eligibility.

Websites:

- Title 24 Regulations: Code of Regulations- Title 24
- California HCD CDBG Guidelines (2019): Community Development Block Grant Final Guidelines

USDA Community Facilities (CF) Direct Loan and Grant Program

- Supports essential infrastructure in rural communities (population under 20,000).
- Eligible activities include fire station construction, seismic retrofitting, and hazard-resistant design.
- EEW integration is not directly funded but may be supported through planning and preparedness components.

  Website: USDA Community Facilities (CF) Direct Loan and Grant Program

References

California Governor's Office of Emergency Services. (2023). *Earthquake Warning California Legislative Report*. https://www.caloes.ca.gov/wp-content/uploads/Earthquake-Tsunami-Volcano/Documents/2023-EEW-Legislative-Report.pdf

Congressional Research Service. (2023). *ShakeAlert: Earthquake early warning system and federal funding* (CRS Report No. R47121). https://www.congress.gov/crs_external_products/R/PDF/R47121/R47121.13.pdf

Federal Emergency Management Agency. (2024). *Pre-Disaster Mitigation Grant Program overview*. https://www.fema.gov/grants/mitigation/learn/pre-disaster

Federal Emergency Management Agency. (2025). *Hazard Mitigation Grant Program overview*. https://www.fema.gov/grants/mitigation/learn/hazard-mitigation

Federal Emergency Management Agency. (2025). *National Earthquake Hazards Reduction Program (NEHRP) overview*. https://www.fema.gov/emergency-managers/risk-management/earthquake/nehrp

U.S. Department of Housing and Urban Development. (2019). *California CDBG final guidelines*. https://www.hcd.ca.gov/sites/default/files/docs/grants-and-funding/CDBG-Final-Guidelines-2019.pdf

U.S. Department of Housing and Urban Development. (n.d.). *Title 24 regulations*. https://www.ecfr.gov/current/title-24

U.S. Department of Agriculture. (2024). *Community Facilities Direct Loan and Grant Program overview*. https://www.congress.gov/crs_external_products/R/PDF/R48462/R48462.2.pdf